

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97303
within 30 days from the date
of well completion.

RECEIVED

STATE OF OREGON
(Please type or print)

6978
M 131.78
State Well No. 752w-11
State Permit No.

FEB 26 1979

(Do not write above this line)

(1) OWNER: WATER RESOURCES DEPT.

Name William C. Evans SALEM, OREGON
Address 7575 Heron Rd. NE
Salem, Oregon 97303

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Rotary Driven
Cable Jetted
Dug Bored
Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

8 " Diam. from top ft. to 140 ft. Threaded Welded
" Diam. from ft. to ft. Gage .250
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills Knife
Size of perforations 3/8 in. by 2 1/2 in.
558 perforations from 80 ft. to 136 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
test approx. 400 GPM for 1 1/2 hours "
" " " " "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Portland Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 9 sacks
How was cement grout placed? Poured in from the top

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 2194
 1/4 1/4 Section 11 T. 7S R. 2W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 75 ft.
Static level 40 ft. below land surface. Date 1/16/79
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Brown Clay	2	32	
Blue Clay	32	44	
Brown Clay	44	64	
Cemented Brown Sand and Gravel	64	75	
Brown Sand and Gravel	75	80	
Dark Brown Sand and Gravel	80	137	
Brown Clay	137	140	

Work started 1/15/79 19 Completed 1/16/79 19
Date well drilling machine moved off of well 1/17/79 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dallas L. Bees Date 1/17/79 , 19____
(Drilling Machine Operator)

Drilling Machine Operator's License No. 752

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Willamette Drilling Co.
(Person, firm or corporation) (Type or print)

Address 7365 O'Neil Rd. NE Salem, Oregon 97303

[Signed] Dallas L. Bees
(Water Well Contractor)

Contractor's License No. 561 Date 1/17/79 , 19____