

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above the line)

RECEIVED
NOV 22 1972

State Well No.

STATE ENGINEER

SALEM OREGON

State Permit No.

75/2W-12

2006
MARI...

(1) OWNER:

Name Clarence Simmons
Address Rta. 2, Silverton, Ore. 97381

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
8" Diam. from 139 ft. to 244.6 ft. Gage # 250
10" Diam. from 17 ft. to (145) ft. Gage # 250
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated Yes No.

Type of perforator used _____
Size of perforations in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Owner

Yield: 120 gal./min. with 98 ft. drawdown after 15 min.

air 150 " 300 " 8 hrs.

with original water cased off & after top

Baller test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used original

Well sealed from land surface to _____ ft.

Diameter of well bore to bottom of seal _____ in.

Diameter of well bore below seal _____ in.

Number of sacks of cement used in well seal _____ sacks

Number of sacks of bentonite used in well seal _____ sacks

Brand name of bentonite _____

Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Marion Driller's well number _____
_____ 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner
Approx. 2500' W, 1750' N. of S. E. cor
of sec 12. T.7S. R.2W.

(11) WATER LEVEL: Completed well.

Depth at which water was first found _____ ft.

Static level 37 ft. below land surface. Date 4-20-72

Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 346 ft. Depth of completed well 346 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
med. sand and gravel grey	140	143	
Clay dark brn. med. hd.	143	152	
clay grey hard	152	155	
clay grey sticky med. hd	155	198	
clay reddish brn. soft	198	233	
Tuffstone firm greyish brn	233	246	
Weathered basalt med. hd.	246	251	
lava red med. hd.	251	263	
weathered basalt brn. md. hd.	263	281	W.B.
basalt grey hd.	281	338	
basalt porous gy. med. hd.	338	346	W.B.

Work started 4-19-72 1972 Completed 5-15-72 1972

Date well drilling machine moved off of well 5-19-72 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Paul R. Stadel Date 11-4, 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 16

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name P. Stadel & Sons, Inc.
(Person, firm or corporation) (Type or print)

Address Rte 3, Box 169, Silverton, Ore.

[Signed] Paul R. Stadel
(Water Well Contractor)

Contractor's License No. 296 Date 11-4, 1972