

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED NOV 12 1968

STATE OF OREGON (Please type or print) Do not write above this line

MARION 7/2w-12aa

State well No. 7/2w-12aa

State Permit No. G-4697

STATE ENGINEER

(1) OWNER: SALEM OREGON

Name Clifford Herr
Address Rt. 2 Box 277 A
Silverton, Ore

(2) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [x] Driven [ ]
Cable [x] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [x] Test Well [ ] Other [ ]

CASING INSTALLED:

1 23/4 Diam. from 340 ft. to 165 ft. Gage 250
Diam. from ft. to ft. Gage
Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? [x] Yes [ ] No.

Type of perforator used Mills
Size of perforations 3/8 in. by 2 in.
204 perforations from 67 ft. to 75 ft.
540 perforations from 75 1/2 ft. to 120 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 23 ft. below land surface Date 11/5/68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [x] Yes [ ] No If yes, by whom? Stettler
620 gal./min. with 68 ft. drawdown after 1 hrs.
550 " 43 " 1 "
500 " 37 " 1/8 "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(10) CONSTRUCTION:

Well seal—Material used Clay
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? [ ] Yes [x] No Depth
Was a drive shoe used? [x] Yes [ ] No
Did any strata contain unusable water? [ ] Yes [ ] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 7/2W-12A
1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 210 ft. Depth of completed well 170 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include Grey clay, Blue clay, Sand & gravel, Brwn clay, Brwn silty sand, Gravel with clay, Clean sand & gravel, Coarse gravel with clay, Clay, Brwn sand, Blue clay, Brwn clay.

Work started 10/9/68 19 Completed 11/5/68 19

Date well drilling machine moved off of well 11/6/68 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Harry A. Robinson Date 11/6/68 19
(Drilling Machine Operator)

Drilling Machine Operator's License No. 63

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson
(Person, firm or corporation) (Type or print)

Address 2214 Front St. NE Salem, Ore.

[Signed] Harry A. Robinson
(Water Well Contractor)

Contractor's License No. 22 Date 11/6/68 19