

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

704  
MARI...

**WATER WELL REPORT**

STATE OF OREGON

(Please type or print)  
(Do not write above this line)



JAN 6 1969

STATE ENGINEER  
SALEM OREGON

State Well No. 7/2w-12 db

State Permit No. \_\_\_\_\_

**(1) OWNER:**

Name Clarence Simmons  
Address Route 2, Silverton, Ore, 97381

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
10" Diam. from 0 ft. to 145 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(6) PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used Mills  
Size of perforations 3/8 in. by 3 in.  
900 perforations from 79 ft. to 139 ft.  
" perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
" perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
" perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
" perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WATER LEVEL: Completed well.**

Static level 19 ft. below land surface Date 12-21-68  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 250 gal./min. with 117 ft. drawdown after 3 hrs.  
" " " " " "  
" " " " " "  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used Bentonite  
Depth of seal 18 ft.  
Diameter of well bore to bottom of seal 14 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(11) LOCATION OF WELL:**

County Marion Driller's well number \_\_\_\_\_  
1/4 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner  
2500, W. 1750, N. of S.E. cor  
of sec 12, T. 7S. R. 2W.

**(12) WELL LOG:**

Diameter of well below casing \_\_\_\_\_

Depth drilled 145 ft. Depth of completed well 145 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil brn.	0	1	
Clay brn.	1	25	
Clay sandy brn.	25	40	
Clay brn sticky.	40	63	
Sandy clay grey.	63	68	
Conglom grey med, W.B.	68	139	
Clay grey.	139	145	

Work started 12-21-68 19 \_\_\_\_\_ Completed 12-21-68 19 \_\_\_\_\_

Date well drilling machine moved off of well 12-21-68 19 \_\_\_\_\_

**Drilling Machine Operator's Certification:**  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ben. Taylor Date 12-21, 1968  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 322

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons  
(Person, firm or corporation) (Type or print)

Address Route 3, Box 169, Silverton, Ore

[Signed] Paul R. Stadel  
(Water Well Contractor)

Contractor's License No. 296 Date 12-26, 1968.