Shiem, treyon	Record	COUNTY Marion APPLICATION NO. GR-913		
M Allenson				
OWNER: Elton L. Watts	MAILING ADDRESS:	Route 2, Box 271		
	CITY AND STATE:	Silverton		
SW 1/4 NW 1/4 Sec. 12 T. 7 S., R. 2 W	WW	ı		
Bearing and distance from section or subdivision	•, •• •••			
corner 1950 feet South and 1300 feet East	from the			
NW Corner, Section 12		_ @		
		E(1)		
·				
Altitude at well				
TYPE OF WELL: Drilled Date Constructed A	pr. 1952			
Depth drilled 125 feet Depth cased 125 fe	et	Section	12	
CASING RECORD:	The second of th	<del></del>		
10-inch steel 0 to 125 feet				
		1		
MINITOIT.				
FINISH: perforated 410 perforations 72 to 12	5 feet			
F	) 100 <b>0</b>			
AQUIFERS:				
gravel 123 to 125 feet				
WATER LEVEL:	And the second s			1
15 feet				
PUMPING EQUIPMENT: Type	Berkley Turbi	ne	н.р. 20	Elec.
Capacity 480 G.P.M.			v.s	. Motor
WELL TESTS:	•	lino		
Drawdown37 ft. after				_
Drawdown 21 ft. after	hours	375		G.P.M.
USE OF WATER Irrigation	Temp °	F	**	, 19
SOURCE OF INFORMATION GR-887 DRILLER or DIGGER J. A. Sneed & Son	ns 2505 Bro	oks Street	Salem	***************************************
ADDITIONAL DATA:	:::::	<u></u>	DOLLOIN	
Logx Water Level Measurements	Chemical Ana	lysis	Aquifer Test	**********
REMARKS:	TO THE RESIDENCE OF THE PARTY O			
Soil 0 72				
Gravel, cemented 72 123				
Gravel, (water) 123 125				