

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

RECEIVED

WATER WELL REPORT

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

JUL 29 1979

STATE OF OREGON

(Please type or print)

WATER RESOURCES DEPT.

(Do not write above this line)

7063
MAY 31 1979

State Well No. 75/2W-14

State Permit No.

(1) OWNER:

Name Henry Beutler c/o G & C Farms
Address 4196 81st Ave. NE
Salem, Oregon 97303

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

10" Diam. from top ft. to 200 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Test 400 GPM for a period of 3 hours
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Portland Cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 15 sacks
How was cement grout placed? poured through tremy pipe for surface seal. After installation of casing, water level remained unchanged at 187' for 3 days. No further seal was felt necessary
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 2211
1/4 1/4 Section 14 T. 7S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 87 ft.
Static level 40 ft. below land surface. Date 5/18/79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 460 ft. Depth of completed well 460 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Brown Clay	2	25	
Blue Clay	25	45	
Brown Clay	45	60	
Brown Gravelly Clay	60	87	
Brown Sandy Clay	87	95	
Brown Gravelly Clay	95	118	
Brown Cemented Sand and Gravel	118	141	
Brwon Sandy XXX Clay	141	158	
Black Sandy Gravel	158	161	
Blue Shale	161	196	
Black Basalt	196	254	
Slightly Fractured Basalt(water)	254	268	
Black Basalt	268	315	
Slightly Fractured Basalt(water)	315	332	
Black Basalt	332	404	
Slightly Fractured Basalt(water)	404	431	
Black Basalt	431	460	

Work started 5/3/79 19 Completed 5/18/79 19
Date well drilling machine moved off of well 5/18/79 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dallas R. Rein Date 5/19/79, 19...
(Drilling Machine Operator)

Drilling Machine Operator's License No. 752

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Willamette Drilling Co.
(Person, firm or corporation) (Type or print)

Address 7365 O'Neill Rd. NE Salem, Oregon 97303

[Signed] Dallas R. Rein
(Water Well Contractor)

Contractor's License No. 561 Date 5/19/79, 19...