NOTICE TO WATER WELL CONTRACTOR The original and first copy

of this report are to be filed with the

STATE OF OREGON
(Please type or print)

APR CO 19state Permit No.

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

within 30 days from the date of well completion. (Do not write abo	ve this line) NATER RESOURCES DEPT.	
	(10) LOCATION OF WELL:	
1) OWNER:	` ' 11 \	
Tame Gerald Koth	County Marion Driller's well nu	
address 4196 8/DT NE Salem.	34 14 Section 14 T. 75	R. $2W$ W.M.
	Bearing and distance from section or subdivisio	n corner
2) TYPE OF WORK (check):		
New Well □ Deepening P Reconditioning □ Abandon □		
f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed we	ell.
3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	ft.
totary Driven Domestic Industrial Municipal	Static level 35 ft. below land st	irface. Date 3-16-76
cable Detect I Jetted I Irrigation Test Well I Other I	Artesian pressure lbs. per square	
		,
CASING INSTALLED: No Threaded Welded	(12) WELL LOG: Diameter of well b	elow casing //
" Diam. from ft. to ft. Gage	Depth drilled 150 ft. Depth of comple	eted well 350 ft.
	Formation: Describe color, texture, grain size a	nd structure of materials;
" Diam. from ft. to ft. Gage	and show thickness and nature of each stratum with at least one entry for each change of format	n and aquifer penetrated,
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate princ	cipal water-bearing strata.
	MATERIAL	From To SWL
Type of perforator used	Basalt	200 240
Size of perforations in. by in.	Broken Basait	240 250
perforations from ft. to ft.	Heneycomb Basalt	252 260
perforations fromft. toft.	Broken Basalt	260 325
perforations from ft. to ft.	Honeycomb Basalt	325 330
(7) SCREENS: Well screen installed? Yes No	Broken Basalt	330 350
Manufacturer's Name		
Type Model No		
Diam Slot size Set from ft. to ft.	· · · · · · · · · · · · · · · · · · ·	
Diam Slot size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? Wes I No If yes, by whom? Stettler Bres		
Yield: 400 gal./min. with 75 ft. drawdown after hrs.		
500 " 125 " "		
" 600 " 200 " "		
Bailer test gal./min. with ft. drawdown after hrs.		
Artesian flow g.p.m.		
perature of water Depth artesian flow encountered ft.	Work started 2-2 1976 Complete	ed 3-/7 1976
	Date well drilling machine moved off of well	3-/7 197
(9) CONSTRUCTION:		
Well seal-Material used	Drilling Machine Operator's Certification: This well was constructed under my	direct supervision
Well sealed from land surface to ft.	Materials used and information reported	above are true to my
Diameter of well bore to bottom of seal in.	best knowledge and belief.	3-17 .71
Diameter of well bore below seal in.	[Signed] / Luc (C. D. F.) Date 3-17, 1978	
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No. 549	
Number of sacks of bentonite used in well seal sacks		
Brand name of bentonite	Water Well Contractor's Certification:	
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report i	
of water	true to the best of my knowledge and belief.	
Did any strata contain unusable water? Yes No Plugs	Name (Person, firm or corporation) (Type or print)	
	Address 4510 Dallag -	Salem Hwy
Type of water? depth of strata	00 - 2/0/	,
Method of sealing strata off	[Signed] (Water Well Cont	2.26~V
Was well gravel packed? Yes No Size of gravel:	•	
Gravel placed from ft. to ft.	Contractor's License No. 13 Date	3 ~ 18 , 1976