

STATE OF OREGON WATER SUPPLY WELL REPORT

(as required by ORS 537.545 & 537.765 and OAR 690-205-0210)

(1) LAND OWNER Owner Well ID. 6567  
 First Name Dennis Last Name Carlson  
 Company Woodburn Organic LLC  
 Address 2229 San Felipe St.  
 City Houston State TX Zip 77019

(2) TYPE OF WORK  New Well  Deepening  Conversion  
 Alteration (complete 2a & 10)  Abandonment (complete 5a)

(2a) PRE-ALTERATION  
 Casing: Dia + From To Gauge Stl Plstc Wld Thrd  
 12 0 240 .250      
 Seal: Cement From To Amt sacks/lbs  
 0 20 6 Sacks

(3) DRILL METHOD  
 Rotary Air  Rotary Mud  Cable  Auger  Cable Mud  
 Reverse Rotary  Other

(4) PROPOSED USE  Domestic  Irrigation  Community  
 Industrial/ Commercial  Livestock  Dewatering  
 Thermal  Injection  Other

(5) BORE HOLE CONSTRUCTION Special Standard  (Attach copy)  
 Depth of Completed Well 233 ft.  
 BORE HOLE SEAL  

Dia	From	To	Material	From	To	Amt	sacks/lbs
						Calculated	
						Calculated	

 How was seal placed: Method  A  B  C  D  E  
 Other  
 Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
 Filter pack from 1 ft. to 233 ft. Material sand Size 8-12  
 Seal Placement Begin Date \_\_\_\_\_ Begin Time \_\_\_\_\_

(5a) ABANDONMENT USING UNHYDRATED BENTONITE  
 Proposed Amount Pounds Actual Amount Pounds

(6) CASING/LINER  

Casing	Liner	Dia	+	From	To	Gauge	Stl	Plstc	Wld	Thrd
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	10		.67	123	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	10		223	232	.250	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	12		1	0	.365	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

 Shoe  Inside  Outside  Other Location of shoe(s) \_\_\_\_\_  
 Temp casing  Yes Dia \_\_\_\_\_ From + \_\_\_\_\_ To \_\_\_\_\_

(7) PERFORATIONS/SCREENS  
 Perforations Method holte air perforator  
 Screens Type V-wire Material stainless  

Perf/S	Casing/ Screen	Liner	Dia	From	To	Scrns/slot width	Slot length	# of slots	Tele/ pipe size
Perf	Casing	Liner	12	132	223	.125	1	5,057	
Screen	Liner	Liner	10	123	223	.03	.03		

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailor  Air  Flowing Artesian  

Yield gal/min	Drawdown	Drill stem/Pump depth	Duration (hr)
800		230	3

 Temperature 59 °F Lab analysis  Yes By \_\_\_\_\_  
 Water quality concerns?  Yes (describe below) TDS amount 165 ppm  

From	To	Description	Amount	Units

(9) LOCATION OF WELL (legal description)  
 County MARION Twp 5 S N/S Range 1 W E/W WM  
 Sec 17 SW 1/4 of the NE 1/4 Tax Lot 700  
 Tax Map Number \_\_\_\_\_ Lot \_\_\_\_\_  
 Lat \_\_\_\_\_ " or 45.13676146 DMS or DD  
 Long \_\_\_\_\_ " or -122.83150015 DMS or DD  
 Street address of well  Nearest address

Next to 11213 Serres Ln NE - Woodburn, OR 97071

(10) STATIC WATER LEVEL  

Existing Well / Pre-Alteration	Date	SWL(psi)	+ SWL(ft)
	02-23-2024		37
Completed Well	02-25-2024		37

 Flowing Artesian?  Dry Hole?

WATER BEARING ZONES Depth water was first found \_\_\_\_\_

SWL Date	From	To	Est Flow	SWL(psi)	+ SWL(ft)

(11) WELL LOG Ground Elevation \_\_\_\_\_  

Material	From	To
starting depth of well 237' perforated existing		
12" casing from 132' - 223'. 8 rows. Cleaned out		
239'. Well naturally filled with sand to 233'.		
Set 10" casing and screen inside existing 12" casing. 124 bags of sand used. Filter packed with sand below 10" casing and around casing and screen to ground level. Added 1' of 12" casing to existing 12" casing. Added pour spout for sand welded plate on bottom 10' casing filter packed 0 to 233'		

 RECEIVED  
 Jones Drilling CO., INC.  
 29400 Santiam Hwy.  
 Lebanon, OR 97355  
 541-367-2560 541-451-2686  
 1-800-915-8388  
 OWRD  
 Construction 2/22/2024  
 Begin Date 02-23-2024 Begin Time 10 00 End Date 02-25-2024

(unbonded) Water Well Constructor Certification  
 I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.  
 License Number 2050 Date 03-19-2024  
 Signed *Joel Taylor*

(bonded) Water Well Constructor Certification  
 I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.  
 License Number 1684 Date 03-19-2024  
 Signed \_\_\_\_\_  
 Contact Info (optional) \_\_\_\_\_