

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

MARI 7.12

WATER WELL REPORT

RECEIVED

JUL 23 1974

State Well No. 451W-22ab

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

STATE ENGINEER
SALEM, OREGON

State Permit No. _____

(Do not write above this line)

Card no 287 June

(1) OWNER:

Name Rick & Gale Zocker
Address R1 130x241
17600th ave

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 180 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used Star
Size of perforations 3/8 x 1 1/2 in. by _____ in.
140 perforations from 173 ft. to 177 ft.
600 perforations from 150 ft. to 167 ft.
200 perforations from 115 ft. to 125 ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. _____
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 3.4 ft.
Diameter of well bore to bottom of seal 1.6 in.
Diameter of well bore below seal 1.2 in.
Number of sacks of cement used in well seal 12 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons _____
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County MARION Driller's well number _____
N41 1/4 NE 1/4 Section 22 T. 49 R. 14 W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 164 ft.
Static level 47 ft. below land surface. Date 7-13-74
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 12
Depth drilled 180 ft. Depth of completed well 180 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP 8011	0	2	
Brown clay	2	24	
Blue clay	24	58	
light blue clay	58	76	
Dark silt	76	88	
Black clay	88	106	
Cement Gravel	106	125	
Blue clay	125	134	
Cement Gravel	134	160	
loose Gravel	160	168	
Blue clay	168	171	
sand & Gravel	171	176	
light Blue clay	176	180	

Work started 7-2 1974 Completed 7-16 1974
Date well drilling machine moved off of well 7-16 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John W Beck Date 7-18, 1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 437

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name J.W. Beck well drilling
(Person, firm or corporation) (Type or print)

Address 24437 3 Skyline Dr. Canby Ore

[Signed] John W Beck
(Water Well Contractor)

Contractor's License No. 449 Date 7-18, 1974