

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON, within 30 days from the date of well completion.

RECEIVED
MAY 6 1969
STATE ENGINEER
SALEM OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
MAY 19 1969
(Do not write above this line)

RECEIVED
MAY 19 1969
STATE ENGINEER
SALEM OREGON

MARTIN should be minor 22 bca
State Well No. 41W-246
State Permit No. G 5230

(1) OWNER:

Name VAN VEEN NURSERY
Address 3127 SE 43RD AVE. PORTLAND, ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 171 ft. Gage 330
11 1/4" Diam. from 167 ft. to 172 ft. Gage 312
10" Diam. from 185 ft. to 192 ft. Gage 279

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name EDWARD E. JOHNSON
Type STAINLESS STEEL Model No. _____
Diam. 12 Slot size 1.20 Set from 172 ft. to 185 ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 40 ft. below land surface Date 4/21/69
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 475 gal./min. with 110 ft. drawdown after 10 hrs.
" " " " " " " "

Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water 56° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CEMENT GROUT
Depth of seal 40 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County CLACKAMAS Driller's well number 4306
NE 1/4 SE 1/4 Section 21 T. 45 R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing ROCK FILLED

Depth drilled 289 ft. Depth of completed well 192 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL	0	2	
BROWN CLAY AND SILT	2	29	
GREY SILT	29	94	
PACKED SILT	94	108	
SILT WITH SOME GRAVEL	108	123	
SAND SCALE GRAVEL	123	138	
CLAY AND GRAVEL	138	146	
GREY SAND AND SILT	146	154	
CEMENTED GRAVEL	154	176	
SAND AND GRAVEL	176	184	
BLUE AND BROWN CLAY	184	289	

Work started MAR 11 1969 Completed APR 28 1969
Date well drilling machine moved off of well MAY 5 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ed Johnson Date MAY 5 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 57

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LANE PORTLAND ORE,

[Signed] Robert L. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date MAY 5 1969