

RECEIVED

MARKI 7132

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT STATE OF OREGON (Please type or print)

State Well No. 7/2w-16 State Permit No.

(1) OWNER:

Name MARVIN VAN CLEAVE Address RT. 2 VAN CLEAVE RD. N.W SALEM ORE

(2) LOCATION OF WELL:

County MARION Driller's well number 1/4 Section 16 T. 7S R. 2W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 135 ft. Gage 4" Threaded [ ] Welded [X]

(7) PERFORATIONS:

Type of perforator used MILLS Perforated? [X] Yes [ ] No Size of perforations 3/8 in. by 25 in. 30 perforations from 60 ft. to 63 ft. 810 perforations from 80 ft. to 135 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE Depth of seal 46 ft. Was a packer used? yes Diameter of well bore to bottom of seal 14 in. Were any loose strata cemented off? [ ] Yes [X] No Depth Was a drive shoe used? [X] Yes [ ] No Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 14 ft. below land surface Date 4-17-65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [X] Yes [ ] No If yes, by whom? STEETLER SUPPLY Yield: 500 gal./min. with 32 ft. drawdown after 1 hrs. 600 " 41 " 1 " 700 " 58 " 1 "

(12) WELL LOG:

Diameter of well below casing Depth drilled ft. Depth of completed well ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOPSOIL, CLAY YELLOW COLOR, CLAY BLUE COLOR SKTY, CONGLOMERATE, GRAVEL SAND 2", SAND + GRAVEL MUDDY, CONGLOMERATE - BLUE, CONGLOMERATE YELLOW, GRAVEL 1", CONGLOMERATE - LU B., GRAVEL COARSE, CONGLOMERATE LU B., GRAVEL 1", CONGLOMERATE.

Work started 4-9-1965 Completed 4-17-1965 Date well drilling machine moved off of well 4-17-1965

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.H. SNEED & SONS (Person, firm or corporation) (Type or print) Address 3910 SILVERTON RD SALEM, OREGON Drilling Machine Operator's License No. 181 [Signed] J.H. Sneed (Water Well Contractor) Contractor's License No. 6 Date 4-19-1965