

STATE OF OREGON WATER SUPPLY WELL REPORT

MARI 71370

WELL I.D. LABEL# L 143594 START CARD # 1073850 ORIGINAL LOG #

9/17/2024

(as required by ORS 537.545 & 537.765 and OAR 690-205-0210)

(1) LAND OWNER Owner Well I.D. 1 First Name ALFRED Last Name POHLSCHNEIDER Company POHLSCHNEIDER FARMS Address 17904 FRENCH PRAIRIE RD NE City ST. PAUL State OR Zip 97137

(2) TYPE OF WORK [X] New Well [] Deepening [] Conversion [] Alteration (complete 2a & 10) [] Abandonment (complete 5a)

(2a) PRE-ALTERATION Dia + From To Gauge Stl Plstc Wld Thrd Casing: Seal:

(3) DRILL METHOD [] Rotary Air [] Rotary Mud [] Cable [] Auger [] Cable Mud [X] Reverse Rotary [] Other

(4) PROPOSED USE [] Domestic [X] Irrigation [] Community [] Industrial/ Commercial [] Livestock [] Dewatering [] Thermal [] Injection [] Other

(5) BORE HOLE CONSTRUCTION Special Standard [] (Attach copy) Depth of Completed Well 340.00 ft.

Table with columns: Dia, From, To, Material, From, To, Amt, Sacks/lbs. Rows include Bentonite Chips and Cement.

Seal placement method [] A [] B [X] C [] D [] E [] Other: Backfill placed from 340 ft. to 373 ft. Material SLOUGH AND SILICA Filter pack from 152 ft. to 285 ft. Material SILICA SAND Size 8/12

(5a) ABANDONMENT USING UNHYDRATED BENTONITE Proposed Amount Actual Amount

(6) CASING/LINER Table with columns: C/L, Dia, From, To, Gauge, Mat. Type, Wld, Thrd, Shoe, Location. Rows C, L, L, L, L.

Temp casing [X] Yes Dia 20 From + [X] 1 To 42

(7) PERFORATIONS/SCREENS Perf/ Casing/ Screen Table with columns: Dia, From, To, Scrn/slot width, Slot length, # of slots, Pipe size.

(8) WELL TESTS: Minimum testing time is 1 hour

Table with columns: Type of Test, Yield (gal/min), Drawdown, Drill Stem/ Pump Depth, Duration (hr). Row: Pump, 903, 162, 247, 4.

Temperature 56 °F Lab analysis [] Yes By Water quality concerns? [] Yes (describe below) TDS amount 160 ppm From To Description Amount Units

(9) LOCATION OF WELL (legal description) County MARION Twp 4.00 S N/S Range 2.00 W E/W WM Sec 32 NE 1/4 of the SW 1/4 Tax Lot 500

(10) STATIC WATER LEVEL Date SWL(psi) + SWL(ft) Existing Well / Pre-Alteration Completed Well 9/16/2024 76

WATER BEARING ZONES Depth water was first found 76.00 SWL Date From To Est Flow SWL(psi) + SWL(ft)

(11) WELL LOG Ground Elevation Material From To Clay, brown 0 13 Clay grey, soft, silty 13 18

Construction Begin Date 5/29/2024 Begin Time 08 00 End Date 9/16/2024

(unbonded) Water Well Constructor Certification I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards.

Signed CODI REED (E-filed)

(bonded) Water Well Constructor Certification I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above.

Signed ERIC SCHNEIDER (E-filed) Drilling Company:

WATER SUPPLY WELL REPORT - Map with location identified must be attached and shall include an approximate scale and north arrow

MARI 71370

9/17/2024

Map of Hole

