

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

State Well No. 75/2W-17ca

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

(Do not write above this line)

State Permit No.

RECEIVED
JAN 23 1975

(1) OWNER:

Name Bernard Stewart STATE ENGINEER
Address 4374 41st N.E. SALEM, OREGON
Salem, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10 " Diam. from +2 1/2 ft. to 169 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills Knife
Size of perforations 1/4 in. by 2 1/2 in.
288 perforations from 97 ft. to 115 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Johnson
Type stainless Model No.
Diam. 8 Slot size .025 Set from 171 ft. to 201 ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Bello Drilling
Field: 260 gal./min. with 41 ft. drawdown after 4 hrs.
360 " 53 " 14 "
" 415 " 62 " 17 "
492 " 75 " 24 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 55 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Neat Cement
Well sealed from land surface to 38 ft.
Diameter of well bore to bottom of seal 23 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 67 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number
NE 1/4 SW 1/4 Section 17 T. 7s R. 2w W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 64 ft.
Static level 4.5 ft. below land surface. Date 4/26/74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 298 ft. Depth of completed well 201 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0	1	
brown clay	1	3	
blue clay	3	4	
gray clay	4	49	
2" gravel&sand	49	56	
tan clay&sand	56	64	
sand&gravel gray clay	64	85	4.5
sand&gravel brown clay	85	115	
cemented gravel tan	115	123	
cemented sand tan clay	123	134	
cemented coarse sand tan	134	173	
sand some gravel	173	203	4.5
clay orange brown	203	209	
course brown sand tan clay	209	220	
sand gravel tan clay	220	229	
sand gravel gray clay	229	252	
gray silty clay	252	264	
cemented sand gravel gray	264	298	

Work started 10/1 1973 Completed 4/30 1974
Date well drilling machine moved off of well 5/10 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Paul Bello Date 6/8, 1974.
(Drilling Machine Operator)

Drilling Machine Operator's License No. 877

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Bello Well Drilling
(Person, firm or corporation) (Type or print)

Address 4783 Coloma Dr. S.E. Salem

[Signed] Paul Bello
(Water Well Contractor)

Contractor's License No. 579 Date 6/8, 1974.

MARI 7163

For Official Use Only:

Received Date:

County Well Log ID #

Well Identification Tag #

Mari 7163

50387

WELL IDENTIFICATION APPLICATION FORM

BUYER/CURRENT WELL OWNER:

Name: Jim West, Water Superintendent, City of Salem Public Works
Mailing Address: 1410 20th Street SE, Building No. 2
City: Salem State: OR Zip: 97302 Phone: (503) 588-6063

NOTE: Well Identification Tag will be sent to the above address unless otherwise specified.

WELL LOCATION:

Latitude Longitude

County: Marion Owner's Well Number (1st or 2nd, etc): San Rees #8
Township: 7 N or S Range: 2 E or W Section 17BB 1/4 NW 1/4 NW

Tax Lot Number: 1700 Type of Well: water supply MUNK monitoring

Address of Well (if different from above): 4850 Somerset Dr. NE, Salem, OR

Does this well have a formal water right associated with it? Yes: X No:

If Yes: Application #: G6222 Permit #: 6-6841 Certificate #: 6-8558

WELL INFORMATION: (do not complete remainder of application if well log is attached)

Start Card Number: MARI-7163 Approx. Construction Date:

Well Constructor:

Name of Land Owner at Time of Construction:

Well Depth (in feet): Static Water Level (in feet):

Diameter of Exposed Well Casing (in inches):

Please Return Completed Form to: Well Identification Program Oregon Water Resources Department 158 12th Street NE Salem, OR 97301-4172

RECEIVED MAY 21 2001 WATER RESOURCES DEPT. SALEM, OREGON