

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

7218  
MARI...  
Mari

RECEIVED

DEC 13 1967

WATER WELL REPORT STATE ENGINEER

STATE OF OREGON  
(Please type or print)

State Well No. 7/2w-18  
State Permit No.

(1) OWNER:

Name HAROLD KLEIN  
Address SNOW FLAKE DRIVE IN.  
3305 LANCASTER DRIVE NE. SALEM OR

(2) LOCATION OF WELL:

County MARION Driller's well number  
1/4 Section 18 T. 7S R. 2W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
andonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
6" Diam. from 0 ft. to 89' ft. Gage 17.02"  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No

Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Model No.  
Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE  
Depth of seal 35' ft. Was a packer used? yes  
Diameter of well bore to bottom of seal 9 1/2 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? IRONY depth of strata 44' to 52'  
Method of sealing strata off

(10) WATER LEVELS:

Static level 15' ft. below land surface Date 2-9-67  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
" " " " "  
Baller test 20 gal./min. with 34 ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date  
Temperature of water 52 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 89' ft. Depth of completed well 89' ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	3
CLAY YELLOW COLOR	3	18
CLAY BLUE COLOR SILTY	18	27
CLAY BLUE STICKY	27	44
CONGLOMERATE	44	52
CLAY YELLOW STICKY	52	56
CLAY BLUE STICKY	56	68
CLAY BLUE SANDY	68	78
CONGLOMERATE	78	88
GRAVEL + SAND 2"	88	89

Work started 2-8- 1967 Completed 2-9- 1967  
Date well drilling machine moved off of well 2-9- 1967

(13) PUMP:

Manufacturer's Name FAIRBANKS MORSE  
Type: JET H.P. 1

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.P. SNEED & SONS  
(Person, firm or corporation) (Type or print)  
Address 3910 SILVERTON RD. SALEM OR

Drilling Machine Operator's License No. 187

[Signed] R.F. Sneed  
(Water Well Contractor)

Contractor's License No. 6 Date 2-9- 1967