

MAR 7374

7/2W-19M

(NOTE) This Log is a copy of the original Log taken from our copy signed

File Original
First
STATE OF OREGON

Calvin V. Kent April 12, 1956

WATER WELL REPORT

State Well No.

STATE OF OREGON

State Permit No.

RECEIVED
MAR 21 1956
STATE ENGINEER
SALEM, OREGON

(1) OWNER:
Name Fischer & Calvin V. Kent
Address Belvedere Gardens - 456 N. Church
Salem, Oregon

(2) LOCATION OF WELL:
County Marion Owner's number, if any—
1/4 1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner
Lot # 6 Belvedere Gardens

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Top 6" Diam. from 151 ft. to 280 ft. Gage 280
Welded Spring Steel Shoe ft. Gage

(7) PERFORATIONS:
Type of perforator used Mills Perforated? Yes No
SIZE of perforations 2 in. by 1/4 in.
304 perforations from 122 ft. to 151 ft.
perforations from 122 ft. to 151 ft.
perforations from 122 ft. to 151 ft.
perforations from 122 ft. to 151 ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name
Type Model No.
p. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 50 ft.
Material used in seal— Puddled Clay
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 21 ft. below land surface Date 4-2-56
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Calvin V. Kent Date 4-12-56
[Signed] Duane P. Tucker Date _____, 19____

(11) WELL TESTS: T. Drawings as per Out with lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" (Note) Pump "Test below " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 56 Was a chemical analysts made? Yes No

(12) WELL LOG: Diameter of well 6 inches.
Depth drilled 151 ft. Depth of completed well 151 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Well was already 51 ft. deep when we moved on it. for which we have no record		
From 51 to 57 ft. Hard cemented Gravel		
From 57 to 60 Sand (Water)		
From 60 to 138 Yellow clay & gravel		
From 138 to 151 Small gravel & clay (Water)		

(Note) PUMP TEST
70 G.P.M. at 100 ft.
80 " at 109
90 " at 123
100 " at 147

Static Water level after pumping
21 ft.

Work started March 12, 1956. Completed April 2 19 56

(13) PUMP:
Manufacturer's Name Bertley Pump P 7 1/2
Type: 602 H Deep Well Turbine P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Willamette Drilling Co.
(Person, firm, or corporation) (Type or print)
Address Rt. 2 Box 333 Salem, Oregon
Driller's well number 243
[Signed] Roy Perkins
(Well Driller)
License No. 2 Date 4-5-56, 19____