

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
DEC 10 1965
STATE ENGINEER
SALEM OREGON

RECEIVED
DEC 13 1965
STATE ENGINEER
SALEM OREGON
G3456

WATER WELL REPORT
STATE WELL No. 4/1w-23P
State Permit No.

(1) OWNER:

Name **Steve Piccardo**
Address **Hubbard, Oregon**

(2) LOCATION OF WELL:

County **Marian** Driller's well number
1/4 Section **23** T. **4S** R. **1W** W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 193 ft. Gage 1/4"
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used **Millknife**
Size of perforations **3/8** in. by **3** in.
40 perforations from 113 ft. to 115 ft.
35 perforations from 138 ft. to 140 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal **Puddled Mud**
Depth of seal **20** ft. Was a packer used? **no**
Diameter of well bore to bottom of seal **16** in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level **65** ft. below land surface Date **12/2/65**
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? **driller**
Yield: **80** gal./min. with **23** ft. drawdown after **4** hrs.
" **150** " **35** " **4** "
" **220** " **48** " **2** "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing **10**
Depth drilled **210** ft. Depth of completed well **210** ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface	0	3
Brown sandy clay	3	88
Broken sand & small gravel	88	93
Blue clay	93	99
Red sand	99	107
Broken sand & gravel	107	116
Blue sandy clay	116	132'6"
Broken gravel & clay	132'6"	138
Gravel	138	140
Blue sandy clay	140	147
Sand	147	149
Grey clay	149	165
Sand (no water)	165	167
Clay	167	196
Sand	196	200
Blue clay	200	210

Work started **Dec Nov 5 1965** Completed **Dec 2 1965**
Date well drilling machine moved off of well **Dec 2 1965**

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME **John Truman Miller**
(Person, firm or corporation) (Type or print)

Address **P O Box 42 Hubbard, Oregon**

Drilling Machine Operator's License No. **26**

[Signed] **John T. Miller**
(Water Well Contractor)

Contractor's License No. **277** Date **December 4**, 19**65**