

RECEIVED

MAR 1 7 442  
MAR 1

7/2 SW - 20

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

JAN 23 1962  
STATE ENGINEER  
SALEM, OREGON  
WATER WELL REPORT  
STATE OF OREGON

State Well No. \_\_\_\_\_  
State Permit No. \_\_\_\_\_

(1) OWNER:

Name OREGON CONFERENCE ASSN. OF SEVENTH-DAY ADVENTISTS,  
Address 605 SE 29th, PORTLAND,

(2) LOCATION OF WELL:

County Mazda Owner's number, if any—  
SE 1/4 SW 1/4 Section 20 T. 7S R. 3W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other  School

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
8 1/2" Diam. from 0-1' ft. to 117 1/2 ft. Gage  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used MILLS  
SIZE of perforations 2 in. by 4 in.  
54 perforations from 116 ft. to 107 ft.  
73 perforations from 107 ft. to 101 ft.  
77 perforations from 101 ft. to 87 ft.  
30 perforations from 87 ft. to 84 1/2 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Was a surface seal provided?  Yes  No To what depth? 64 ft.  
Material used in seal— Drilling Mud  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 22 1/2 ft. below land surface Date 5/25/61  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by:

[Signed] Joseph H. Anderson Date Sept. 10, 1961  
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "  
" " " " " "  
Ballor test 70 gal./min. with 1 1/2 ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well 8 inches.  
Depth drilled 122 ft. Depth of completed well 122 ft.  
Formation: Describe by color, character, size of material and structure; and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	1
Brown Clay	1	18
Blue Clay	18	32
Blue Clay with Sand and some gravel	32	36
Brown Clay with Sand and some gravel	36	45
Brown Clay	45	64
Sand, gravel with some Clay	64	77
Blue Clay	77	84
Sand, gravel with some Clay	84	122

Work started 5/15 1961. Completed 5/25 1961

(13) PUMP:

Manufacturer's Name Fairbanks, Morse  
Type: SLC1-58 Submersible H.P. 5

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George H. Robinson Drilling  
(Person, firm, or corporation) (Type or print)

Address 3965 Hayesville Dr. Salem

Driller's well number 52561-

[Signed] George H. Robinson  
(Well Driller)

License No. 335 Date 5/25, 1961