

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

NOV 8 1976

State Well No. 73/2w-20

State Permit No.

(1) OWNER:

Name Greg Oldham

Address 2230 Chemawa Rd NE
Salem Oregon 97303

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Cable ☒ Dug ☒Driven ☐ Jetted ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒6" Diam. from 1 ft. to 89 ft. Gage 1250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ NoManufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static levelWas a pump test made? ☐ Yes ☒ No If yes, by whom?

Well: gal./min. with ft. drawdown after hrs.

" " " "

Ball test 40 gal./min. with 30 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite & 1/4 minus

Well sealed from land surface to 40 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 0 sacks

Number of sacks of bentonite used in well seal 2 sacks

Brand name of bentonite Western Hills

Number of pounds of bentonite per 100 gallons

of water lbs./100 gals.

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

WATER RESOURCES DEPT.

(10) LOCATION OF WELL:

County Marion

Driller's well number

1/4 1/4 Section 20 T. 7S R. 24 W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 85 ft.

Static level 25 ft. below land surface. Date Oct 25

Artesian pressure lbs. per square inch. Date 8

(12) WELL LOG:

Diameter of well below casing

Depth drilled 89 ft. Depth of completed well 89 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
brown clay	0	8'	
brown sandy clay	8'	25'	
gray clay	25'	55'	
gray sand + silt	55'	70'	
clay brown	70'	80'	
cemented brown	80'	85'	
gravels			
loose gravels small	85'	89'	25'
med			

Work started Oct 20 19 76 Completed Oct 25 19 76

Date well drilling machine moved off of well Oct 26 19 76

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Harold Peel Date Oct 27 19 76

(Drilling Machine Operator)

Drilling Machine Operator's License No. 924

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name ROBINSON'S EOLA WELL DRILLING

(Please Print Name and Address)

(Type or print)

Address SALEM, OREGON

[Signed] George H. Robinson

(Water Well Contractor)

Contractor's License No. 13 Date 10-29 1976