

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE ENGINEER, SALEM 10, OREGON
 within 30 days from the date of well completion.

State Well No. 7/2W-30K

State Permit No. G 3484

(1) OWNER:

Name OTTO FOLK
 Address 5492 SWEEPLE RD. N.E. SALEM ORE

(2) LOCATION OF WELL:

County MARION Driller's well number
 NW 1/4 OF SE 1/4 Section 20 T. 7S R. 2W W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
 Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
 Cable ☒ Jetted ☐
 Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☒
 8" Diam. from 0 ft. to 167 ft. Gage 24"
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ No

Type of perforator used MILLS
 Size of perforations 5/8 in. by 2 1/2 in.
 48 perforations from 37 ft. to 39 ft.
 832 perforations from 60 ft. to 160 ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
 Type Model No.
 m. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
 Depth of seal 34' ft. Was a packer used? YES
 Diameter of well bore to bottom of seal 12" in.
 Were any loose strata cemented off? ☐ Yes ☒ No Depth
 Was a drive shoe used? ☒ Yes ☐ No
 Was well gravel packed? ☐ Yes ☒ No Size of gravel:
 Gravel placed from ft. to ft.
 Did any strata contain unusable water? ☐ Yes ☒ No
 Type of water? Depth of strata
 Method of sealing strata off

(10) WATER LEVELS:

Static level 10' ft. below land surface Date 12-3-64
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? ☒ Yes ☐ No If yes, by whom? STETTLER SUPPLY

Yield: 135 gal./min. with 93 ft. drawdown after 1 hrs.
 " 150 " 107 " 1 "

Baller test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 54° Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 167' ft. Depth of completed well 167' ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
CLAY YELLOW COLOR	2	25
CLAY BLUE COLOR	25	34
GRAVEL COARSE W.B.	34	39
CLAY YELLOW COLOR	39	53
CONGLOMERATE-WITH CLAY 50% - INTERMITTENT WATER VEINS	53	167

CONGLOMERATE FROM 53' TO 167'
 UNUSUALLY TIGHT.

(13) PUMP:

Manufacturer's Name
 Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED & SONS
 (Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. SALEM ORE.

Drilling Machine Operator's License No. 187

[Signed] J. A. Sneed
 (Water Well Contractor)

Contractor's License No. 6 Date 12-3-1964