

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED MAY 7 1969 STATE ENGINEER SALEM, OREGON

WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

7466 MAR 7 1969 State Well No. 7/2W-20 State Permit No.

(1) OWNER:

Name F.R. PATTERSON Address 1185 BOND RD.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:

6" Diam. from 41 ft. to 132 ft. Gage 250. Threaded [] Welded [X]

(6) PERFORATIONS:

Type of perforator used Mills Size of perforations 3/8 in. by 1 1/2 in. 536 perforations from 75 ft. to 129 ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 20 ft. below land surface Date 4-18-69 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [X] Yes [] No If yes, by whom Robinson & West Yield: 500 gal./min. with 65 ft. drawdown after 2 1/2 hrs.

(10) CONSTRUCTION:

Well seal—Material used CEMENTED Depth of seal 22 ft. Diameter of well bore to bottom of seal 14 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 1/4 Section 20 T. 9, S R. 2, W W.M. Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 8 Depth drilled 132 ft. Depth of completed well 132 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: BROWN - CLAY (0-17), Blue - SANDY (17-43), BROWN - CEMENTED (43-47), BLACK - SAND + SMALL GRAVEL (47-56), BROWN - CLAY (56-59), GRAY - (59-79), BROWN - MED. GRAVEL (79-96), BROWN - CEMENTED (96-100), BROWN - MED. GRAVEL (100-115), BROWN - CEMENTED (115-118), BROWN - MED. GRAVEL (118-122), BROWN - CEMENTED (122-132).

Work started 4-8-1969 Completed 4-18-1969 Date well drilling machine moved off of well 4-19-1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Maxine Crest Date 4-24, 1969 (Drilling Machine Operator)

Drilling Machine Operator's License No. 158

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME Miller - Robinson & West (Person, firm or corporation) (Type or print) Address 5545 Forest St. S.E. Salem [Signed] Arthur R. Miller (Water Well Contractor) Contractor's License No. 37 Date 4-24, 1969