

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print) (Do not write above this line)

RECEIVED FEB 13 1970

MARIAN 7469

State Well No.

State Permit No.

1/2 W-206a

STATE ENGINEER SALEM, OREGON

(1) OWNER:

Name Jack Teggert Address 2611 35th N.E. Salem

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [X] Municipal [] Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:

7" Diam. from 71 ft. to 118 ft. Gage 025

(6) PERFORATIONS:

Perforated? [X] Yes [] No. of perforator used Mills Size of perforations 3/8 in. by 2 in. 104 perforations from 89 ft. to 95 ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 11 ft. below land surface Date 2-2-70 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No If yes, by whom? Field: gal./min. with ft. drawdown after hrs.

(10) CONSTRUCTION:

Well seal—Material used Benomite Depth of seal 20 ft. Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Marion Driller's well number NE 1/4 NW 1/4 Section 20 T. 75 R. 2W W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing Depth drilled 119 ft. Depth of completed well 119 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: Brown Clay (0-25), Blue Sandy Clay (25-45), Cemented Gravel (45-49), Gravel & Sand (49-53), SAND (53-55), Cemented Gravel (55-61), Brown Clay (61-73), Cemented Gravel (73-89), Small to Large Gravel (Some SAND) (89-95), Cemented Gravel (95-109), Med + Large Gravel (109-115), Cemented Gravel (115-117), Grey Clay (117-119).

Work started 1-14 19 70 Completed 2-2 19 70 Date well drilling machine moved off of well 2-2 19 70

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] [Signature] Date 2-3, 19 70 (Drilling Machine Operator)

Drilling Machine Operator's License No. 455

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George Robinson Drilling (Person, firm or corporation) (Type or print)

Address 1734 72nd St SE Salem

[Signed] [Signature] (Water Well Contractor)

Contractor's License No. 13 Date 2/4, 19 70

Jacuzzi

OREGON PUMP & EQUIPMENT CO
2338 PRINGLE ROAD
SALEM, OREGON 97302

TELEPHONE: 585-2434

RECEIVED
FEB 25 1970
STATE ENGINEER
SALEM, OREGON

2/18/70

Well test for Jack Taggart at proposed Mobile
Home Park, Sunnyview Ave. Salem .

Static level 15 ft.

11:10 A M start pump at 98 GPM Draw down 5ft.
12:10 A M increase to 200GPM Draw down 2 ft.
1;10 PM increase to 225 GPM Draw down 1 ft.
2:10 PM increase to 250 GPM Draw down 2 ft.
2:50 to 3:10 gradual increase to
550 GPM Draw Down 15 ft.
3:30 PM Shut down


Well recovery to 15ft. 1min 15 sec.

In each increase the water clouded and cleared
in aprox 5 min.

Sample gallon taken 5 min before shutdown.

Oregon Pump and Equip. Co

Alvin Lueb



COPY