

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT STATE OF OREGON

MAR 1958 7487 MAKI

State Well No. 7/2W-20R(1) State Permit No. G-1011

(1) OWNER:

Name Arnold W. Meyer Address 5795 Center St. Salem, Oregon

(2) LOCATION OF WELL:

County Marion Owner's number, if any-- SE 1/4 SE 1/4 Section 20 T. 7 S. R. 2 W. W.M. Bearing and distance from section or subdivision corner

State Permit # G-1011

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

Threaded [ ] Welded [X] 10" Diam. from Top ft. to 163 ft. Gage 31.20#

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No Type of perforator used MILLS SIZE of perforations 1/4 in. by 1 1/4 in. 870 perforations from 69 ft. to 163 ft.

(8) SCREENS:

Well screen installed [ ] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [X] Yes [ ] No To what depth? 12 ft. Material used in seal- Puddled Clay Did any strata contain unusable water? [ ] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 35 ft. below land surface Date 11-24-58 Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Arnold W. Meyer Date Nov 26, 1958 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [ ] No If yes, by whom? Driller Yield: gal./min. with ft. drawdown after hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 56 Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG:

Diameter of well 10 inches. Depth drilled 163 ft. Depth of completed well 163 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Top Soil (0-3), Brown Clay (3-12), Brown Sandy Clay (12-45), Brown Clay (45-60), Brown Sand (60-66), Brown Clay & Gravel (66-68), Gravel (Mostly Tight-and hard) (68-163)

\*\*\*PUMP TEST\*\*\*

140 G.P.M. @ 84 ft. 175 " @ 110 ft. 225 " @ Max.

Work started 10-8-58 19 Completed 11-24-58

(13) PUMP:

Manufacturer's Name Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Max Wymore (Person, firm, or corporation) (Type or print)

Address Rt. 2 Salem, Oregon

Driller's well number 459

[Signed] Max Wymore (Well Driller)

License No. 24 Date 11-24-58, 19