## WATER WELL REPORT STATE OF OREGON

## RECEIVED

ORT 7513 OCT 271980

MARINARI WATER RESOURCES DEPT SALEM, OREGON

State Permit No.

		_
(1) OWNER:	(10) LOCATION OF WELL:	
Name HAROLD SCHIPPOREIT	County MARION Driller's well number 80-12-R	
Address 2000 HAMPDEN LANE	4 NW 4 Section 21 T. 7 S R. 2 W W.	
City SALEM, OREGON 97303 State	Tax Lot # Lot Blk Subdivision	
(2) TYPE OF WORK (check):	Address at well location:	
	2000 HAMPDEN LANE, SALEM, ORE 97303	
New Well Deepening Reconditioning Abandon	(11) WATER LEVEL: Completed well.	
If abandonment, describe material and procedure in Item 12.	Depth at which water was first found 50	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 30 ft. below land surface. Date 9-16-8	8
. / Air Driven 🗆 Domestic 🗆 Industrial 🗆 Municipal 🗆	Artesian pressure lbs. per square inch. Date	
Koury Mud   Dug   Irrigation 🖫 Test Well   Other   Cable   Bored   Thermal: Withdrawal   Reinjection	(12) WELL LOG: Diameter of well below casing 0	_
	75 (1.13)	
) CASING INSTALLED: Steel  Plastic  Threaded  Welded X	Formation: Describe color, texture, grain size and structure of materials; and she	ft
0"Diam.from + 1 ft. to 150 ft. Gauge .250	thickness and nature of each stratum and aquifer penetrated, with at least one ent	tr
	for each change of formation. Report each change in position of Static Water Lev and indicate principal water-bearing strata.	ve
LINER INSTALLED:	MATERIAL From To SWI.	
	TOP SOIL From To SWL	_
	BROWN CLAY 2 48	_
(6) PERFORATIONS: Perforated? T Yes \( \text{No} \)	BROWN SANDY CLAY 28 23	_
Type of perforator used TORCH	BROWN CLAY 23 30	
Size of perforations 4 in. by 4 in.	GREY CLAY 30 50	_
240 perforations from 130 ft. to 150 ft.	BLACK SAND & GRAVEL 50 150 30	_
perforations from	30 130 30	_
perforations from ft. toft.		_
(7) SCREENS: Well screen installed? ☐ Yes 🛎 No		
Manufacturer's Name		
Type Model No	·	
Diam. Slot Size Set from ft. to ft.		
Diam. Slot Size Set from ft. to ft.  Drawdown is amount water level is lowered		
WELL TESTS: below static level		
Was a pump test made? □ Yes 🎇 No If yes, by whom?		
ld: gal./min. with ft. drawdown after hrs.		
" " "		_
Air test 300 gal./min. with drill stem at 130 ft. 1 hrs.		
x test gal./min. with ft. drawdown after hrs.		
tesian flow g.p.m.		
nperature of water 52 Depth artesian flow encountered ft.	Work started 9-14 19 80 Completed 10-16 19 8	8
(9) CONSTRUCTION: Special standards: Yes 2 No [	Date well drilling machine moved off of well 10-16 19 8	
Well seal—Material usedBENTONITE	Drilling Machine Operator's Certification:	_
Well sealed from land surface to	This well was constructed under my direct supervision. Materials use	نم
Diameter of well bore to bottom of seal	and information reported above are true to my best knowledge and belief	f.
Diameter of well bore below seal1Q in.	[Signed] Corilling Machine Operator) Date 10-24, 19.80	Q.
Number of sacks of cement used in well seal	Drilling Machine Operator's License No. 978.	
How was cement grout placed? PRESSURE GROUTED FROM BOTTOM		
LVESSOVE GYOOTED LYON DOTTON	Water Well Contractor's Certification:	
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	to
Was pump installed? Type HP Depth ft.	•	
Was a drive shoe used? XYes \( \Bar{\text{No}}\) Plugs Size: location ft.	Name .FLORES WELL DRILLING. (Person, firm or corporation) (Type or print)	٠
Did any strata contain unusable water?	Address12143RIVERRD.N.E.,GERVIAS97026	
Type of Water? depth of strata  Method of sealing strata off	[Signed] Thomas D Flores	
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	(Water Well Contractor)	
Pennel placed from # to #	Contractor's License No. 5.90 Date	Ų.