

RECEIVED

MARI. 7586
MARI

NOTICE TO WATER WELL CONTRACTOR NOV 18 1965

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 7/2w-21N

State Permit No.

(1) OWNER:

Name OTTO FOLK
Address 5492 SWEELE RD. SALAMA

(2) LOCATION OF WELL:

County MARRION Driller's well number
1/4 Section 21 T. 7S R. 2W. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 127 ft. Gage 1/4"

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS TYPE
Size of perforations 1/4 in. by 2 1/2 in.
810 perforations from 65 ft. to 124 ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
Depth of seal 56 ft. Was a packer used? YES
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 35 ft. below land surface Date 11-15-65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Ballor test 60 gal./min. with 4 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 55 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 127 ft. Depth of completed well 127 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	2
CLAY YELLOW COLOR	2	28
CLAY BLUE COLOR	28	41
CLAY YELLOW SANDY	41	48
CLAY YELLOW STICKY	48	61
CONGLOMERATE	61	64
GRAVEL + SAND 2"-	64	65
CONGLOMERATE	65	70
GRAVEL 2"-	70	71
CONGLOMERATE W.B.	71	127

Work started 11-6 1965 Completed 11-15-1965
Date well drilling machine moved off of well 11-15-1965

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED + SONS (Person, firm or corporation) (Type or print)
Address 3910 SILVERTON RD. SALAM O.
Drilling Machine Operator's License No. 187
[Signed] J.A. Sneed (Water Well Contractor)
Contractor's License No. 6 Date 11-15-1965