

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED
DEC 15 1966
STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON
(Type or print)

MAR 7 628
MAR
G-3756

State Well No. 7/2w-22D
State Permit No.

(1) OWNER:

Name **RAYMOND GERIG**
Address **1992 - 63rd N.E.**
SALEM, OREGON

(2) LOCATION OF WELL:

County **MARION** Driller's well number **II85**
¼ Section **22** T. **7S** R. **2 W** W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from **TOP** ft. to **98** ft. Gage **250**
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used **MILLS**
Size of perforations **3/8** in. by **2** in.
216 perforations from **72** ft. to **97** ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Model No.
..... Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal **CEMENT & PUDDLE CLAY**
Depth of seal **20** ft. Was a packer used?
Diameter of well bore to bottom of seal **10** in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level **35** ft. below land surface Date **II/23/66**
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? **DRILLER**
Yield: **350** gal./min. with **45** ft. drawdown after **4** hrs.
" **250** " " **40** " " **4** "
" **200** " " **30** " " **4** "
Ballor test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing
Depth drilled **98** ft. Depth of completed well **98** ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	3
YELLOW CLAY	3	18
BLUE CLAY & SHALE	18	30
DARK GRAY SANDY SHALE	30	52
BROWN SAND	52	54
BROWN SAND & GRAVEL, SHALE	54	72
BROWN SAND & GRAVEL	72	75
BROWN SAND & GRAVEL & MUD	75	78
BROWN SAND & GRAVEL CEMENTED	78	96
LOOSE BROWN SAND & GRAVEL	96	98

Work started **OCT 21 1966** Completed **NOV 23 1966**
Date well drilling machine moved off of well **NOV. 23 1966**

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME **WILLAMETTE DRILLING CO**
(Person, firm or corporation) (Type or print)

Address **RT. 2 BOX 276 SALEM, OREGON**

Drilling Machine Operator's License No. **74**

[Signed] **Emil O. Beier**
(Water Well Contractor)

Contractor's License No. **2** Date **NOV 23 1966**