

MAR 7 1966

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT STATE OF OREGON JAN 31 1966

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Well No. 7/2w-27N State Permit No.

(1) OWNER: STATE ENGINEER SALEM OREGON Name Lyman Behut Address 6840 State St. Salem, Ore.

(2) LOCATION OF WELL: County Marion Driller's well number 154 SW 1/4 SW 1/4 Section 27 T. 7S R. 2W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): Well [x] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other [] (5) TYPE OF WELL: Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED: 8" Diam. from 0 ft. to 115 ft. Gage .250

(7) PERFORATIONS: Perforated? [x] Yes [] No Type of perforator used Mills Size of perforations 500 in. by 2 in. 500 perforations from 55 ft. to 110 ft.

(8) SCREENS: Well screen installed? [] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal Bentonite Depth of seal 24 ft. Was a packer used? no Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 42 ft. below land surface Date 1/15/66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? Stettler Yield: 140 gal./min. with 50 ft. drawdown after 1 hrs. Baller test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG: Diameter of well below casing 8" Depth drilled 125 ft. Depth of completed well 125 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include Top soil, Heavy clay (brown), Gravel & clay (firm), Clay (soft-brown), Sandstone (firm-red brown), Cement gravel, Silted gravel, Cement gravel (loose spots), Claystone (red-gritty).

Work started 12/13/65 19 Completed 1/15/66 19 Date well drilling machine moved off of well 1/15/66 19

(13) PUMP: Manufacturer's Name Berkeley Type: Submersible H.P. 5

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Pete Tolmasoff Well Drilling (Person, firm or corporation) (Type or print) Address Turner, Ore. Drilling Machine Operator's License No. 320 [Signed] (Water Well Contractor) Contractor's License No. 410 Date 1/15/66 19