NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

7820 MIRI...

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED
DEC 3 1976
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 7S/2W 28

State Permit No.

(1) OWNER:
Name Richard Massey
Address 1774 82 St SE Salem

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from +1 ft. to 95 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" 40 " 35 " "
Bailer test 40 gal./min. with 35 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 0 sacks
Number of sacks of bentonite used in well seal 1 1/2 sacks
Brand name of bentonite Western
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Marion Driller's well number
¼ ¼ Section 28 T. 7S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 91 ft.
Static level 28 ft. below land surface. Date Oct 14, 76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 95 ft. Depth of completed well 95 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
top soil	0	2'	
brown clay	2'	15'	
brown sandy clay	15'	23'	
gray blue clay	23'	45'	
gray clay and cobbles	45	58'	
brown cemented gravel small-med	58'	91'	
Loose gravels small	91	95	28'
med coarse brown sand			

Work started Oct 12 1976 Completed Oct 14 1976
Date well drilling machine moved off of well Oct 14 1976

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Thomas R Rear (Drilling Machine Operator) Date Oct 15, 1976
Drilling Machine Operator's License No. 921

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name ROBINSON'S EOLA WELL DRILLING (Type or print)
Address SALEM, OREGON 97304
[Signed] George H. Robinson (Water Well Contractor)
Contractor's License No. 13 Date 10-15, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119