

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED STATE ENGINEER SALEM, OREGON JUL 17 1967

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 7/2W-28

State Permit No.

STATE ENGINEER SALEM, OREGON

G 5238

(1) OWNER:

Name LEO CHMART. Address 694 HIGH ST. N.E. SALEM, ORE.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [X] Irrigation [] Test Well [] Other []

CASING INSTALLED:

10" Diam. from 0 ft. to 134' ft. Gage 1/2"

PERFORATIONS:

Perforated? [X] Yes [] No.

Type of perforator used MILLS Size of perforations 3/8" in. by 2 1/2" in. 520 perforations from 74' ft. to 130' ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 49' ft. below land surface Date 6-30-67

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom STETTLER SUPPLY Yield: 100 gal./min. with 79 ft. drawdown after 1 1/2 hrs.

Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [X] No

(10) CONSTRUCTION:

Well seal-Material used BENTONITE. Depth of seal 35' ft. Diameter of well bore to bottom of seal 14" in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MARION Driller's well number 1/4 1/4 Section 28 T. 7.5 R. 20 W.M. Bearing and distance from section-or subdivision corner

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 153' ft. Depth of completed well 153' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include TOPSOIL, CLAY YELLOW, CONGLOMERATE, CLAY SANDY-BROWN, CLAYSTONE BROWN FIRM, CLAY YELLOW STICKY, CLAY BLUE, CONGLOMERATE, GRAVEL 1 1/2", CONGLOMERATE, GRAVEL 1 1/2", CONGLOMERATE, BASALT WEATHERED.

Work started 6-20-1967 Completed 6-30-1967

Date well drilling machine moved off of well 6-30-1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] R. F. Sneed Date 6-30-1967 (Drilling Machine Operator)

Drilling Machine Operator's License No. 187

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED & SONS (Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. SALEM, ORE.

[Signed] R. F. Sneed (Water Well Contractor)

Contractor's License No. 6 Date 6-30-1967