

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

AUG 8 1974

STATE OF OREGON

(Please type or print)

STATE ENGINEER

SALEM, OREGON

State Well No.

State Permit No.

75/2W-28b

G 7056

(1) OWNER:

Name A.M. HARRISON
Address 5583 BASIL ST
SALEM ORE.

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 96 ft. Gage 4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom? SNEED BROS

Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Bailer test 31 gal./min. with 44 ft. drawdown after 1 1/2 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used WELL SEAL
Well sealed from land surface to 42' ft.
Diameter of well bore to bottom of seal 10" in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal NONE sacks
Number of sacks of bentonite used in well seal 13 sacks
Brand name of bentonite WELL SEAL
Number of pounds of bentonite per 100 gallons
of water 100 lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs NONE Size: location ft.
Did any strata contain unusable water? ☒ Yes ☐ No
Type of water? SANDY depth of strata 49' to 69'
Method of sealing strata off CASEP
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County MARION Driller's well number
1/4 NW 1/4 Section 28 T. 7S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 88' ft.
Static level 51 ft. below land surface. Date 8-5-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 95'6" ft. Depth of completed well 95'6" ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOPSOIL	0	2	
CLAY YELLOW COLOR	2	42	
CONGLOMERATE	42	49	
CLAY YELLOW SANDY	49	69	
CONGLOMERATE	69	88	
SAND + GRAVEL 1" -	88	90	51
BASALT BROKEN	90	95'6"	51

Work started 8-1-1974 Completed 8-5-1974
Date well drilling machine moved off of well 8-5-1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] R. J. Sneed Date 8-5-1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 187

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name J. A. SNEED & SONS
(Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD, SALEM ORE

[Signed] R. J. Sneed
(Water Well Contractor)

Contractor's License No. 6 Date 8-5-1974