NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED OCT 29 1970 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

7926 MARION

State Well No. 7/2W-29

State Permit No.

(1) OWNER:
Name Elmer Stoller
Address Rt.1 Box 313
Independence, Ore.

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
10 3/4" Diam. from 1½ ft. to 28 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 10 gal./min. with 47 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite & clay
Well sealed from land surface to 28 ft.
Diameter of well bore to bottom of seal 14" to 18 ft & 12" to 28 ft
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal ½ sacks
Number of sacks of bentonite used in well seal ½ sacks
Brand name of bentonite Aquagel
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Polk Driller's well number 7/2W-29R
¼ ¼ Section 29 T. 7S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 52 ft.
Static level 33 ft. below land surface. Date 10/16/70
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 10
Depth drilled 100 ft. Depth of completed well 100 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil	0	2	
Grey-brown clay	2	20	
Blue clay--sticky	20	25	
Siltstone-grey	25	75	
Sandstone-light grey	75	85	
Siltstone-grey	85	100	

Work started 10/13 1970 Completed 10/16/70 19
Date well drilling machine moved off of well 10/16/70 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Harry A. Robinson Date 10-21, 1970
(Drilling Machine Operator)
Drilling Machine Operator's License No. 63

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Harry A. Robinson (Person, firm or corporation) (Type or print)
Address 2214 Front St NE Salem, Ore.
[Signed] Harry A. Robinson
(Water Well Contractor)
Contractor's License No. 22 Date 10/21/70, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119