

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

**RECEIVED** MARI...  
**WATER WELL REPORT**

AUG 20 1964  
STATE OF OREGON  
(Please type or print)

State Well No. 7/2w-29

State Permit No. \_\_\_\_\_

(1) OWNER: DALE STUART  
Name SALEM GOLF LAND INC.  
Address 5220 CENTER ST N.E.  
SALEM ORE.

(2) LOCATION OF WELL:  
County MARION Driller's well number \_\_\_\_\_  
1/4 Section 29 T. 7S R. 2W · W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:  
8" Diam. from 0 ft. to 110 ft. Gage 4"  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_"  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_"

(7) PERFORATIONS:  
Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations 5/16 in. by 2 1/2 in.  
544 perforations from 6.0 ft. to 107 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:  
Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
Well seal—Material used in seal BENTONITE  
Depth of seal 39' ft. Was a packer used? yes  
Diameter of well bore to bottom of seal 12" in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:  
Static level 35' ft. below land surface Date 8-22-64  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? STETTLER SUPPLY  
Yield: 200 gal./min. with 18 ft. drawdown after 1 hrs.  
" 430 " 34 " 1 "  
" 590 " 60 " 1 "  
Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water 54° Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well below casing 8"  
Depth drilled 110' ft. Depth of completed well 110' ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL          | FROM | TO  |
|-------------------|------|-----|
| TOPSOIL           | 0    | 3   |
| CLAY YELLOW COLOR | 3    | 26  |
| CLAY BLUE COLOR   | 26   | 39  |
| CONGLOMERATE      | 39   | 47  |
| CLAY YELLOW COLOR | 47   | 50  |
| CLAY BLUE COLOR   | 50   | 57  |
| CONGLOMERATE      | 57   | 67  |
| GRAVEL COARSE     | 67   | 70  |
| CONGLOMERATE U.B. | 70   | 83  |
| GRAVEL COARSE     | 83   | 85  |
| CONGLOMERATE U.B. | 85   | 110 |

Work started 8-17 1964 Completed 8-22 1964  
Date well drilling machine moved off of well 8-22 1964

(13) PUMP:  
Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME S. A. SNEED & SONS  
(Person, firm or corporation) (Type or print)  
Address 3910 SILVERTON RD. SALEM, O.  
Drilling Machine Operator's License No. 187  
[Signed] S. A. Sneed  
(Water Well Contractor)  
Contractor's License No. 6 Date 8-22, 1964