

Original
File Original and
Duplicate with the
STATE ENGINEER,
SALEM, OREGON

Attention 170 12th St. **RECEIVED**
STATE ENGINEER

8106
M. M. A. K.
State Well No. 73W-27A(2)
State Permit No.

(1) OWNER:
Name Pacific Telep. & Tel. Co. OREGON
Address 509 S.W. Corbett St.
Portland, Ore

STATE ENGINEER

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Stettler
Yield: 36 gal./min. with 80 ft. drawdown after 24 hrs.
" 35 " " 46 " " 1 "
" 35 " " 31 " " 1 "
Bailey test 50 gal./min. with 11 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 56 Was a chemical analysis made? Yes No

(2) LOCATION OF WELL:
County Clatsop Owner's number, if any _____
Section _____ W.M. _____
Lot 6, Block 17, University Addition to
Salem. In Cottage Street 8' north of
south property line and 3.5' west of
west property line

(12) WELL LOG:
Diameter of well 10 inches.
Depth drilled 110 ft. Depth of completed well 110 ft.

TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

(4) PROPOSED USE (check): Domestic Industrial Municipal
Test Well Other
(5) TYPE OF WELL: Rotary Driven
Cable Jetted
Dug Bored

MATERIAL	FROM	TO
Sand & gravel with clay pressed into it	0	45
Andesitic-basalt very hard and sandy	45	107 1/2
Illahee siltstone	107 1/2	110
Gravel range in size as large as cantelope		

CASING INSTALLED: Threaded Welded
1 3/4" Diam. from 0 ft. to 45 ft. Gage # 279
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used Wills
SIZE of perforations 3/8 in. by 2 in.
180 perforations from 25 ft. to 44 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION:
Well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal- _____
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 13 ft. below land surface Date 3/6//58
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: RC Henry Date 3/18/58
[Signed] _____ (Owner)

Work started 2/17.58 19 Completed 3/7/58 19

(13) PUMP:
Manufacturer's Name _____ H.P. _____
Type: _____

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Harry A. Robinson
(Person, firm, or corporation) (Type or print)
Address 2214 N. Front St.
Driller's well number 7/3W-27B2
[Signed] Harry A. Robinson
(Well Driller)
License No. 22 Date 3/7/58, 19.