

RECEIVED APR 11 1961

WELL # 3

81357

STATE ENGINEER

WATER WELL REPORT STATE OF OREGON

State Well No. 7/3W-31N(1) State Permit No.

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER: ILLAHE COUNTRY CLUB Name Address

(2) LOCATION OF WELL: County Marion Owner's number, if any - SW 1/4 SW 1/4 Section 31 T. 7 S R. 3 W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check): Domestic [] Industrial [] Municipal [X] Irrigation [] Test Well [] Other [] (5) TYPE OF WELL: Rotary Cable [] Dug [] Driven Jettied [] Bored []

(6) CASING INSTALLED: Threaded [] Welded [X] 10" Diam. from 0 ft. to 49 ft. Gage 32#

(7) PERFORATIONS: Perforated? [X] Yes [] No Type of perforator used MILLS TYPE SIZE of perforations 3/8 in. by 2 1/2 in. 260 perforations from 31 ft. to 41 ft.

(8) SCREENS: Well screen installed [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [X] Yes [] No To what depth? 6' + Material used in seal - PUMP COVERED Did any strata contain unusable water? [] Yes [X] No Type of water? Depth of strata Method of sealing strata off CASED + BACK FILLED

(10) WATER LEVELS: Static level 16 ft. below land surface Date 3-31-61 Artesian pressure lbs. per square inch Date

Log Accepted by: [Signed] Gilbert G... Date April 7, 1961 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level. Was a pump test made? [X] Yes [] No If yes, by whom? STETTLER SUPPLY Yield: 300 gal./min. with 11 ft. drawdown after 1 hrs. 450 " 19 " 3 "

(12) WELL LOG: Diameter of well 10" 1-0 inches. Depth drilled 76' ft. Depth of completed well 76' ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOP SOIL, CLAY-YELLOW-SANDY, SAND-MEDIUM GRAIN, SAND+GRAVEL 25% SAND, GRAVEL #3, CONGLOMERATE 3", WATER GRAVEL + SAND 3", CLAY STONE-GRAY FIRM, CLAY STONE BLUE HARD, CLAY STONE SOFT.

CLAY STONE FROM 72' TO 76' DEEP - + WATER BEARING 50 GPM

Work started 3-29 1961 Completed 3-31 1961

(13) PUMP: Manufacturer's Name Type: H.P.

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED + SONS (Person, firm, or corporation) (Type or print) Address 2505 BROOKS ST. SALEM OREG. Driller's well number [Signed] B.J. Sneed (Well Driller) License No. 6 Date 3-32, 1961