

RECEIVED
JUL 14 1959

MIRI 8/15/59
MARK

Appl # 1513
7/3W-33 M(2)

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. _____
State Permit No. _____

(1) OWNER:

Name Salem Golf Club
Address A3 Salem

(2) LOCATION OF WELL:

County _____ Owner's number, if any—
1/4 1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Comment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

Threaded Welded
1.0" Diam. from 1 ft. to 4.0 ft. Gage 4
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
SIZE of perforations in. by in.
144 perforations from 26' ft. to 32' ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

SCREENS:

Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(8) CONSTRUCTION: yes

Was well gravel packed? Yes No Size of gravel: 2"
Gravel placed from 25' ft. to 30' ft.
Was a surface seal provided? Yes No To what depth? 2' +
Material used in seal— PUMP COVERED
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off CASED + BACK FILL

(10) WATER LEVELS:

Static level 15' ft. below land surface Date 7-1-59
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] Salem Golf Club Date July 11, 1959
Ed Key
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level STERILE
Was a pump test made? Yes No If yes, by whom? SUPPLY
Yield: 450 gal./min. with 20 ft. drawdown after 9 hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 55° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 10" I.P. inches.
Depth drilled 90' ft. Depth of completed well 90' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	3	3
CLAY YELLOW COLOR	14	17
CLAY BLUE COLOR	6	23
SAND FINE GRAIN	3	26
WATER GRAVEL #3"	6	32
SHALE BLUE COLOR	26	58
SANDSTONE GRAY	10	68
SANDSTONE WHITE	10	78
SANDSTONE GRAY	10	88
SHALE BLUE COLOR	2	90

415-G.P.M FROM 26' TO 32'
20 " @ 58'
10 " @ 70'
5 " @ 87'

Work started 6-29 1959 Completed 7-1 1959

(13) PUMP:

Manufacturer's Name BERKLEY
Type: TURBINE H.P. 5

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.H. SNEED + SONS
(Person, firm, or corporation) (Type or print)

Address 2505 BROOKS ST. SALEM, O.

Driller's well number _____

[Signed] J.H. Sneed
(Well Driller)

License No. 6 Date _____, 19____