

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

MAR 8 1963

State Well No. 4/1W-28

State Permit No. _____

(1) OWNER:

Name Norman Wilson

Address Rte 4 Box 46
Sherwood, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number _____
1/4 Section 28 T. 4S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
.....16" Diam. from0 ft. to150 ft. Gage 1/4"
....." Diam. from ft. to ft. Gage _____
....." Diam. from ft. to ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Millknife
Size of perforations 3/8 in. by 2 in.
.....104 perforations from 141'6" ft. to 145'6" ft.
.....156 perforations from 108 ft. to 114 ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Mud
Depth of seal 25 ft. Was a packer used? no
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 26 ft. below land surface Date 4/18/63
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? driller
Yield: 800 gal./min. with 75 ft. drawdown after 8 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 150 ft. Depth of completed well 150 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface	0	3
Brown sandy clay	3	35
Blue sandy clay	35	65
Black sand	65	75
Blue sandy clay	75	107
Gravel	107	114
Blue clay	114	118
Black sand	118	128
Small gravel & sand	128	133
Broken gravel	133	146
Blue sandy clay	146	150

Work started 3/13 1963 Completed 4/18 1963
Date well drilling machine moved off of well 4/16 1963

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller
(Person, firm or corporation) (Type or print)

Address P.O. Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 277

[Signed] John T. Miller
(Water Well Contractor)

Contractor's License No. 26 Date 4/18, 1963