

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

8354 MARI...

WATER WELL REPORT

RECEIVED

75/15-9

STATE OF OREGON (Please type or print)

FEB 5 - 1976

State Well No.

WATER RESOURCES DEPT. SALEM, OREGON (Do not write above this line) 6-7146

(1) OWNER:

Name Ernest Klopfenstein Address 11745 Kaufman Rd. N.E. Silverton, Oregon 97381

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Rotary [X] Driven [] Cable [] Jetted [] Dug [] Bored [] Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(10) LOCATION OF WELL:

County Marion Driller's well number S.W. 1/4 S.W. 1/4 Section 9 T. 7 S R. 1 E W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 45 ft. Static level 39 ft. below land surface. Date 10/24/75 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 222 ft. Depth of completed well 222 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Topsoil, Clay brn., Conglon. gry. med., Basalt gry. hrd., Basalt brn. wthrd., Basalt gry. hrd.

CASING INSTALLED: 2" Diam. from 1 ft. to 24 ft. Gage 250

PERFORATIONS: Perforated? [] Yes [X] No. Size of perforations in. by in.

(7) SCREENS: Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No Yield: gal./min. with ft. drawdown after hrs. Air test 100 gal./min. with 1 hrs. Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: Well seal—Material used Cement Well sealed from land surface to 24 ft. Diameter of well bore to bottom of seal 10 in. Number of sacks of cement used in well seal 7

Work started 10/21 1975 Completed 10/24 1975 Date well drilling machine moved off of well 10/24 1975

Drilling Machine Operator's Certification: This well was constructed under my direct supervision. [Signed] Steve Stadel Date 10-28 1975

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. [Signed] Paul R. Stadel Date 10-28 1975