NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

8427 MARI

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
JUL 23 1973
STATE ENGINEER
SALEM OREGON

State Well No. 7S/3W-17
State Permit No.

(1) OWNER:
Name Roger Behrke
Address 2635 Walker Rd
Salem Ore

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from +8 ft. to 90 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 24 gal./min. with 54 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 55 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 2½ sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water 30 lbs./100 gals.
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Marion Driller's well number
¼ ¼ Section 17 T. 7S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 49 ft.
Static level 37 ft. below land surface. Date 18 July 73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6 in
Depth drilled 91 ft. Depth of completed well 91 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Topsoil	0	4	
Brown Sandy Clay	4	22	
Blue Clay	22	49	
Sand & Gravel	49	54	25
Gravel & Blue Clay	54	56	
Black sand & pea gravel	56	62	
Grey Clay	62	65	
Brown Sand - dirty	65	83	35
Large & Pea - Gravel	83	90	37
brown Clay & Gravel	90	91	

Work started 16 July 1973 Completed July 17 1973
Date well drilling machine moved off of well July 18 1973

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Leonard J. Terrell (Drilling Machine Operator) Date July 18, 1973
Drilling Machine Operator's License No. 862

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Robinsons Edd Drilling (Person, firm or corporation) (Type or print)
Address 4510 Dallas Rd NW
[Signed] George H. Robinson (Water Well Contractor)
Contractor's License No. 13 Date 7-19, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119