

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
 STATE ENGINEER
 SALEM, OREGON
 OCT 22 1970
 Do not write above this line

STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date of well completion.

STATE ENGINEER OF OREGON
 (Type or print)

8459
 MA 31...
 G 5346

State Well No. 7/1-26cd
 State Permit No.

(1) OWNER:
 Delbert Hupp
 Name Star Rt Silverton, Oreg
 Address

(2) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
 Rotary Driven Domestic Industrial Municipal
 Cable Jetted Irrigation Test Well Other
 Dug Bored

CASING INSTALLED:
 Threaded Welded
 " Diam. from 0 ft. to 205 ft. Gage .250
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

PERFORATIONS:
 Perforated? Yes No.
 Type of perforator used Torch
 Size of perforations 3/8 in. by 6 in.
 24 perforations from 185 ft. to 205 ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:
 Well screen installed? Yes No
 Manufacturer's Name
 Type Model No.
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
 Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 30 gal./min. with 10 ft. drawdown after 16 hrs.
 " " " " " "
 " " " " " "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m.
 Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
 & cuttings
 Cement & XXXX
 Well seal—Material used
 Well sealed from land surface to 20 ft.
 Diameter of well bore to bottom of seal 10 in.
 Diameter of well bore below seal 8 in. 7.205'
 Number of sacks of cement used in well seal sacks
 Number of sacks of bentonite used in well seal sacks
 Brand name of bentonite
 Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
 County Marion Driller's well number
 1/4 1/4 Section T. R. W.M.
 Bearing and distance from section or subdivision corner
 2200'E. & 300'N. of S.W. cor Sec 26, T. 7, S.

(11) WATER LEVEL: Completed well.
 Depth at which water was first found 195 ft.
 Static level 181 ft. below land surface. Date 10/6/70
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
 Depth drilled 221 ft. Depth of completed well 221 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil red	0	2	
Clay red	2	16	
Weathered Basalt brn.	16	21	
H.B. basalt grey	21	60	
H. claystone brn.	60	66	
" " " green	66	73	
" " " brn.	73	79	
H. basalt grey	79	84	
M. weathered basalt brn.	84	108	
H. basalt grey	108	125	
H. sandstone grey	125	133	
M. weathered basalt brn.	133	203	W.B. 190
H. basalt grey	203	221	204

Work started 9/28/70 19 Completed 10/6/70 19
 Date well drilling machine moved off of well 10/6/70 19

Drilling Machine Operator's Certification:
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
 [Signature] Date 10/20/70
 (Drilling Machine Operator)
 Drilling Machine Operator's License No. 322

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 Name R. Stadel & Sons (Person, firm or corporation) (Type or print)
 Address Silverton, Oreg.
 [Signature] Paul R. Stadel (Water Well Contractor)
 Contractor's License No. 296 Date 10/20/70 19