

WATER WELL REPORT
STATE OF OREGON

RECEIVED

MAR 9 1983

M 71
85/1W-14

State Well No.

State Permit No.

WATER RESOURCES DEPT. PRINT IN INK
SALEM, OREGON

(1) OWNER:

Name TONY HENDRICKS
Address 13773 Silver Falls Hwy S.E.
City Sublimity State Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
 Bored Thermal: Withdrawal ReInjection

(4) PROPOSED USE (check):

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded
8" Diam. from +1 1/2 ft. to 49 ft. Gauge .250

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Air Test May Fluctuate
Air test 800 - 1000 gal./min. with drill stem at 222 ft. 1 1/2 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used Cement
Well sealed from land surface to 49 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 20 sacks
How was cement grout placed? Air Grout Pump

Was pump installed? NO Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number
1/4 Section 14 T. 8S R. 1W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 13773 Silver Falls Hwy S.E.
Sublimity, Oregon

(11) WATER LEVEL: Completed well.

Depth at which water was first found 85 ft.
Static level 30 ft. below land surface. Date 2-16-83
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 222 ft. Depth of completed well 222 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	2	
Brown Clay	2	6	
Tan Clay	6	13	
Red Clay	13	27	
White Sticky Clay	27	31	
Tan Clay	31	33	
Decomposed Rock	33	39	
Black Basalt	39	85	
Black Vesicular Basalt	85	102	
Black Basalt	102	222	30'

Work started 1-31 19 83 Completed 2-3 19 83
Date well drilling machine moved off of well 2-16 19 83

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date, 19

Bonded Water Well Constructor Certification:

Bond (number) Issued by: Surety Company Name
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name MILLER, WEST WELL DRILLING
(Person, firm or corporation) (Type or print)
Address 5875 Gaffin Rd S.E. Salem, Oregon
[Signed] J.D. Mendera
Water Well Constructor
Date 3-9, 19 83