NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

8745 M

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED JUN 25 1974 STATE ENGINEER SALEM, OREGON

State Well No. 85/1W-18
State Permit No.

(1) OWNER:
Name EUGENE KELLEY
Address Rt. 2 - Box 22A
AUMSVILLE ORE.

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from +1 ft. to 49 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
AIR " " "
~~Bailer~~ test 30 gal./min. with 200 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT + DRILL CUTTINGS
Well sealed from land surface to 48 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal 0 sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County MARION Driller's well number
¼ ¼ Section 18 T. 8 S R. 1 W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 65 ft.
Static level 32 ft. below land surface. Date 5-3-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 243 ft. Depth of completed well 243 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
RED - TOP SOIL + DECOMPOSED ROCK WITH SOME BOULDERS	0	49	
BLACK - BASALT ROCK	49	65	
RED - DECOMPOSED ROCK (SOFT)	65	70	
GRAY - CLAYSTONE	70	78	
" + BLACK - BASALT WITH THIN SOFT LAYERS	78	243	

Work started 5-1 1974 Completed 5-3 1974
Date well drilling machine moved off of well 5-3 - 1974

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Marion West (Drilling Machine Operator) Date 5-3, 1974
Drilling Machine Operator's License No. 188

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name MILLER + WEST (Person, firm or corporation) (Type or print)
Address 5875 GAFFIN RD. S.E. SALEM
[Signed] Harlan R. Miller (Water Well Contractor)
Contractor's License No. 37 Date 5-7-, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119