	M1. 31	**************************************	
of this report are to be the WATER WELL REPORT 8/14 - 26 K			
state well No			
(1) OWNER: SALEM. OREGON	(11) WELL TESTS: Drawdown is amount water level is lowered below static level		
Name Gerald Heuberger	Was a pump test made? Y Yes I No If yes, by whom? Stettler		
Address	Yield: 320 gal./min. with 720 ft. drawdown after 4 hrs.		
Sublimity, Ore.	······································		
(2) LOCATION OF WELL:	Bailer test gal./min. with ft. drawdown after hrs.		
County Marion Driller's well number 8/1W-26K	Artesian flow g.p.m. Date		
<u> </u>	Temperature of water Was a chemical analysis made?	Yes No	
Bearing and distance from section or subdivision corner	- (12) WELL LOG: Diameter of well below casing		
<u></u>	Depth drilled 260 ft. Depth of completed well 260 ft.		
• • •	Formation: Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.		
	MATERIAL	и то	
(3) TYPE OF WORK (check):	(Dec) 2	
New Well K Deepening 🗌 Reconditioning 🗋 🐪 Abandon 🗌	Basalt, fresh badly	<u></u>	
Is indonment, describe material and procedure in Item 12.	fractured	2 115	
(4) PROPOSED USE (check): (5) TYPE OF WELL:	Basalt (fresh) grey 11	5 171	
Domestic 🗍 Industrial 📋 Municipal 📋 Rotary 🗋 Driven 🗌	Basalt (fresh) Blk. 17	L 260	
Irrigation IV Test Well Coher			
(6) CASING INSTALLED: Threaded WeldedX			
8 5/8" Diam. from 14 ft. to 341 ft. Gage 250		-	
" Diam. fromft. toft. Gage		· · · ·	
"Diam. from ft. to ft. Gage	· · ·		
(7) PERFORATIONS: Perforated? [] Yes X] No			
Type of perforator used			
Size of perforations in. by in.		·····	
perforations from It. to It. to It.	·		
perforations from			
perforations from			
perforations from ft. to ft.			
(8) SCREENS: Well screen installed? Ves X No			
Manufacturer's Name			
TModel No.			
D. Slot size Set from ft. to ft.	Work started 7 /21 19 65 Completed 8/21	5 1965	
Diam	Date well drilling machine moved off of well 8/26/65	19	
(9) CONSTRUCTION:	(13) PUMP:		
Well seal-Material used in seal			
Depth of sealft. Was a packer used?XOS	Manufacturer's Name		
Diameter of well bore to bottom of seal	H.P		
Were any loose strata cemented off? 🗋 Yes 🏝 No Depth	Water Well Contractor's Certification:		
Was a drive shoe used? 🗌 Yes 📑 No	This well was drilled under my jurisdiction and this report is		
Was well gravel packed? 🗌 Ycs 🕱 No 🦳 Size of gravel:			
Gravel placed from ft. to ft.	(Person, firm or corporation) (Type or print)		
Did any strata contain unusuable water? 🗌 Yes 🗋 No	(Person, firm or corporation) (Type or print) Address 2214 Front St. NE Salem. Ore.		
Type of water? depth of strata	- Adaress <u>ccttt tt vite by</u> , MG D&Lem, UI'e.		
Method of sealing strata off	Drilling Machine Operator's License No		
(10) WATER LEVELS:	Isimult be and Plan		
Static level 80 ft. below land surface Date 8/25/65			
Artesian pressure lbs. per square inch Date Contractor's License No. 22 Date 9/2/65, 19			
(USE ADDITIONAL SHEETS IF NECESSARY)			