

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED
 NOV 22 1965
 STATE ENGINEER
 SALEM OREGON

MIR 9/22

WATER WELL REPORT

STATE OF OREGON
 (Please type or print)

G-3313

State Well No. 920-33N
 State Permit No. G-3085

(1) OWNER:

Name Santiam Golf Club
 Address Sublimity, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number _____
 1/4 Section T. R. W.M.
 Bearing and distance from section or subdivision corner
750 ft N, 600 ft E, of S.W. cor of
sec 33, T9S, R2W of W.M.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
 Irrigation Test Well Other Cable Jetted
 Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
10 " Diam. from 0 ft. to 100 ft. Gage 279
8 " Diam. from 95 ft. to 235 ft. Gage 250
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Mills
 Size of perforations 3/8 in. by 4 in.
890 perforations from 18 ft. to 80 ft.
120 perforations from 102 ft. to 165 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
 _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite & cuttings
 Depth of seal 18 ft. Was a packer used? no
 Diameter of well bore to bottom of seal 14 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level II ft. below land surface Date 10-6-65
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
 Yield: 205 gal./min. with 119 ft. drawdown after 3 hrs.

Bailer test gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow g.p.m. Date _____

Temperature of water XX Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 330 ft. Depth of completed well 330 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil.	0	3
Cobble stones, & clay, brn.	3	36
Med congl, brn.	36	70
Loose gravel, & small boulders.	70	76
Clay, brn.	76	95
Med clay stone, grey.	95	135
Hard clay stone, dark grey.	135	165
Med clay stone, dark grey.	165	185
Med clay stone, light grey.	185	213
Med clay stone, green.	213	220
Hard basalt, black.	220	255
Soft clay stone, black.	255	256
Med basalt, black.	256	300
Med clat stone, blue.	300	305
Med basalt, black.	305	330

Work started 9-10 1965 Completed 10-6 1965
 Date well drilling machine moved off of well 10-6 1965

(13) PUMP:

Manufacturer's Name _____ ?
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadeli & Sons
 (Person, firm or corporation) (Type or print)

Address Rt # 3, Box 169, Silverton, Ore

Drilling Machine Operator's License No. 84-322

[Signed] Paul R. Stadeli
 (Water Well Contractor)

Contractor's License No. 296 Date 11-13 1965