

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 APR 20 1965 STATE OF OREGON (Please type or print)

MX 81.9/35

State Well No. 8/1w-33J State Permit No. G3085

(1) OWNER:

Name Triumph Inc. Address Sublimity, Ore.

(2) LOCATION OF WELL:

County Marion Driller's well number 8/1w-33J 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X]

12 3/4" Diam. from 140 ft. to 97 ft. Gage .250

(7) PERFORATIONS:

Perforated? [] Yes [X] No

Type of perforator used

Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Drilling mud & Bentonite Depth of seal 20 ft. Was a packer used? no Diameter of well bore to bottom of seal 16 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 0 ft. below land surface Date 4/17/65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? Stettler Yield: 575 gal./min. with 152 ft. drawdown after 1 hrs. " 500 " 122 " 1 " " 400 " 92 " 1 " Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 335 ft. Depth of completed well 335 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top soil, Yellow clay, Tuff stone weathered, grading into fresh, Tuff stone, Basalt (fresh), Basalt vesicular, Basalt (fresh), Tuffs, Basalt vesicular, Basalt (fresh), Basalt (fresh very hard), Basalt vesicular.

12" hole drilled to 303 8" hole drilled from 303 335

Short bailer tests @ 220-268-285-320 ft showed increase in water flow as drilling progressed.

Work started 3/20/65 19 Completed 4/17/65 19 Date well drilling machine moved off of well 4/17/65 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson (Person, firm or corporation) (Type or print) Address 2214 Front St. NE Salem, Ore.

Drilling Machine Operator's License No. 63

[Signed] Harry A. Robinson (Water Well Contractor)

Contractor's License No. 22 Date 4/19/65 19