

RECEIVED AUG 1 1961

STATE ENGINEER SALEM, OREGON WATER WELL REPORT

MIRI. 9/53 State Well No. 8/1W-34A State Permit No. C-2419

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER:

Name Jean Buttler Address 350 E. Church Sublimity, Ore.

(2) LOCATION OF WELL:

County Marion Owner's number, if any- 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [] Deepening [x] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [] Industrial [x] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [x] 6 5/8" Diam. from ... ft. to ... ft. Gage ... 280.

(7) PERFORATIONS:

Perforated? [] Yes [x] No Type of perforator used SIZE of perforations in. by in. perforations from ... ft. to ... ft.

(8) SCREENS:

Well screen installed [] Yes [x] No Manufacturer's Name Type Model No. Slot size Set from ... ft. to ... ft.

(9) CONSTRUCTION:

Was well gravel packed? [] Yes [] No Size of gravel: Gravel placed from ... ft. to ... ft. Was a surface seal provided? [] Yes [] No To what depth? Material used in seal- Did any strata contain unusable water? [] Yes [] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 93 ft. below land surface Date 7/25/61 Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Jean Buttler Date 7/25/61 1961 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 25 gal./min. with 2 ft. drawdown after 1 1/2 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well 6 inches. Depth drilled 260 ft. Depth of completed well 260 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Row 1: Basalt or Andesite (fresh), 200, 260

Work started 7/18/61 19 Completed 7/25/61 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson (Person, firm, or corporation) (Type or print)

Address 2214 N. Front Salem, Ore.

Driller's well number 8/1W-34A1

[Signed] Harry A. Robinson (Well Driller)

License No. 22 Date 7/26/61 19