STATE ENGINEER Salem, Oregon OWNER: Ray Hartman ADDRE	APPLICATION NO. GR-225
LOCATION OF WELL: Owner's No. 1 STATE SE 1/4 NW 1/4 Sec. 3/4 T. 8 S., R. 1 W., W.M. Bearing and distance from section or subdivision corner 50 feet North and 100 feet West from the center of Section 3/4	AND
Altitude at well 538 feet Interpolated TYPE OF WELL: Drilled Date Constructed Sept. 1954 Depth drilled 215 Depth cased 85 CASING RECORD: 8 inch casing set from 0 to 85 feet	Section34
FINISH:	
AQUIFERS: no record	
WATER LEVEL: 57 feet below land surface November 13, 1954 PUMPING EQUIPMENT: Typenew_pump_to_be_instal Capacity 200 G.P.M.	led soon 10-15 HP H.P
WELL TESTS: Drawdown 100 ft. after hours. Drawdown 200 ft. after hours.	pumping 105 G.P.M " 145 G.P.M
USE OF WATER Irrigation 18 acres Temp. SOURCE OF INFORMATION GR-208 DRILLER or DIGGER unknown ADDITIONAL DATA: Log _no Water Level Measurements Chem	

REMARKS: