

STATE OF OREGON  
**WATER WELL REPORT**  
 (as required by ORS 537.765)

**REGULATIVE**  
 MAR 12 1987  
 WATER RESOURCES DEPT  
 SALEM, OREGON

85/2W-1ac  
 M1 R1...9191

**(1) OWNER:** Owner's Well Number: \_\_\_\_\_  
 Name Gary Kaufman  
 Address P.O. Box 3154  
 City Salem, Or. State Or Zip 97302

**(2) TYPE OF WORK:**  
 New Well  Deepen  Recondition  Abandon

**(3) DRILL METHOD:**  
 Rotary Air  Rotary Mud  Cable  Other

**(4) PROPOSED USE:**  
 Domestic  Community  Industrial  Irrigation  
 Geothermal  Injection  Other

**(5) BORE HOLE CONSTRUCTION:**  
 Depth of Completed Well 630 ft.  
 Special Standards date of approval NA

HOLE Diameter	From		To		Material	SEAL From		To		Amount sacks or pounds
	meter	ft.	meter	ft.		meter	ft.	meter	ft.	
12	0		40		cmt	0		40		26

How was seal placed? Method  A  B  C  D  E  
 Other NA

Backfill placed from NA ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
 Gravel placed from NA ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

**(6) CASING/LINER:**

Casing/Liner	Diameter	From	To	Gauge	Steel		Plastic		Welded		Threaded	
					□	□	□	□	□	□	□	□
Casing: <u>8</u>	<u>+1</u>	<u>40</u>	<u>1/2</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Liner: <u>NA</u>					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Location of shoe(s) \_\_\_\_\_

**(7) PERFORATIONS/SCREENS:**  
 Perforations Method NA  
 Screens Type NA Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
<u>NA</u>						<input type="checkbox"/>	<input type="checkbox"/>

**(8) WELL TESTS: Minimum testing time is 1 hour**  
 Pump  Bailer  Air  Flowing Artesian

Yield gal/min	Pumping level	Drill stem at	Time 1/2 hr
<u>600</u>		<u>630</u>	<u>1 hr</u>
<u>540</u>		<u>500</u>	
<u>500</u>		<u>400</u>	

Temperature of water \_\_\_\_\_ Depth Artesian Flow Found \_\_\_\_\_  
 Was a water analysis done?  Yes By whom NA  
 Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other NA  
 Depth of strata: \_\_\_\_\_

**(9) LOCATION OF WELL by legal description:**  
 County Maricopa Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
 Township T8S N or S, Range R2W E or W, WM.  
 Section 1 SW 1/4 NE 1/4  
 Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
 Street Address of Well (or nearest address) 1/4 mile east on Deschutes drive off of Howelle Prairie

**(10) STATIC WATER LEVEL:**  
135 ft. below land surface. Date 2-18-87  
 Artesian pressure \_\_\_\_\_ lb. per square inch. Date NA

**(11) WELL LOG:** Ground elevation \_\_\_\_\_

Material	From	To	WB?	SWL
Soil med some sod	0	2		
Cobbles, fract rock	2	8		
Clay, loose cobbles	8	32		
Basalt hard gry	32	86		
Basalt visic gry-grn	86	102		
Basalt hard gry	102	114		
Basalt visic gry-brn	114	143		
Basalt weathrd brn	143	156		
Basalt hard gry	156	292		
Basalt gry visic	292	314	H2O	20GPM
Basalt hard gry	314	513		
Basalt hard semi frt	513	560	H2O	120 GPM
Basalt hard gry	560	613		
Basalt weathrd brn	613	625	H2O	500GPM
Basalt hard gry	625	630		

Date started 2-11-87 Completed 2-18-87

**(unbonded) Water Well Constructor Certification:**  
 I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.  
 Signed Steve Stadeli Date 2-23-86

**(bonded) Water Well Constructor Certification:**  
 I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.  
 Signed Chuck Stadeli Date 2-23-87  
 Company Staco Well Services Co. Job No. 87-3