NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

M1 21...9205

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED APR 30 1968 STATE ENGINEER SALEM, OREGON

RECEIVED MAY 24 1968 STATE ENGINEER SALEM, OREGON

State Well No. 8/2w-1

State Permit No.

(1) OWNER:
Name ELDON COLE
Address 8501 McAuliffe Rd. S.E.

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☑
6" Diam. from +1 ft. to 60 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☑ Yes ☐ No.
Type of perforator used TORCH
Size of perforations 1/4 in. by 8 in.
perforations from ft. to ft.
13 perforations from 40 ft. to 59 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 6 1/2 ft. below land surface Date 3-6-68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
AIR " " "
~~Bailer~~ test 30 gal./min. with 55 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(10) CONSTRUCTION:
Well seal—Material used BENTONITE + 1/4-CRUSHED ROCK
Depth of seal 40 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☐ Yes ☑ No
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☑ Yes ☐ No Size of gravel: 3/4" Rounded
Gravel placed from 40 ft. to 60 ft.

(11) LOCATION OF WELL:
County Marion Driller's well number
1/4 1/4 Section NW 1/4 T. 8 S R. 2 W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 73 ft. Depth of completed well 73 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Soil	0	1	
ORANGE - CLAY	1	15	
BROWN - ROCK (Completely weathered)	15	57	
BLACK - PARTLY WEATHERED ROCK	57	73	

Work started 3-4-68 19 Completed 3-6-68 19
Date well drilling machine moved off of well 3-6-68 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Lee Robinson (Drilling Machine Operator) Date 3-6, 19 68
Drilling Machine Operator's License No. 64

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Merill R. Robinson + Wesst (Person, firm or corporation) (Type or print)
Address 5545 Fosdick St. S.E. Salem
[Signed] Marlan R. Miller (Water Well Contractor)
Contractor's License No. 37 Date 3-6-68, 19

(USE ADDITIONAL SHEETS IF NECESSARY)