

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date
of well completion.

RECEIVED

JUN 27 1969

STATE OF OREGON

(Please type or print)

(Do not write above this line)

STATE ENGINEER SALEM, OREGON

State Well No. 8/2W-3

State Permit No.

(1) OWNER:

Name DALE DECKER
Address 274-Box 124 SALEM

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

6" Diam. from 41 ft. to 60 ft. Gage 1250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☒ Yes ☐ No.

Type of perforator used TORCH
Size of perforations 3 in. by 6 in.

10 perforations from 35 ft. to 53 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 40 ft. below land surface Date 5-7-69

Man pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

Air " " "

Packer test 12 gal./min. with 50 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Cemented

Depth of seal 30 ft.

Diameter of well bore to bottom of seal 10 in.

Were any loose strata cemented off? ☐ Yes ☒ No DepthWas a drive shoe used? ☐ Yes ☒ NoDid any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/4"

Gravel placed from 30 ft. to 53 ft.

(11) LOCATION OF WELL:

County Marion Driller's well number

1/4 1/4 Section 3 T. 8 S R. 2, 4 W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 92 ft. Depth of completed well 92 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Soil	0	1	
ORANGE - CLAY	1	15	
- Boulders	15	30	
Brown - weathered	30	50	
cut Rock			
BLACK - ROCK PARTLY	50	60	
(WEATHERED)			
BLACK - BASALT ROCK	60	92	

Work started 5-6-1969 Completed 5-7-1969

Date well drilling machine moved off of well 5-7-1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Geo. Robinson Date 5-8-1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 64

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller - Robinson - West
(Person, firm or corporation) (Type or print)

Address 5545 Joseph St. S.E. Salem

[Signed] Harold R. Miller
(Water Well Contractor)

Contractor's License No. 37 Date 5-8-1969