NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

9487

State Well No. 8S/2W-4dd

State Permit No. .....

RECEIVED OCT 19 1977 WATER RESOURCES DEPT. SALEM, OREGON

(1) OWNER:
Name Chester Smith
Address 6751 MacKay Rd. S.E. Salem, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from +1 ft. to 46 ft. Gage 250
" Diam. from ..... ft. to ..... ft. Gage .....
" Diam. from ..... ft. to ..... ft. Gage .....

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name .....
Type ..... Model No. .....
Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.
Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
~~Bailer~~ Air test 20 gal./min. with 88 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ..... ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 46 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? Air grout pump
Was a drive shoe used? ☒ Yes ☐ No Plugs ..... Size: location ..... ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

(10) LOCATION OF WELL:
County Marion Driller's well number
SE ¼ SE ¼ Section 4 T. 8S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 85 ft.
Static level 65 ft. below land surface. Date 10-4-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 153 ft. Depth of completed well 153 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
Tan Clay with Boulders	1	26	
Brown Clay with Decomposed Rock	26	39	
Gray Basalt Rock	39	133	
Black Basalt Rock	133	153	

Work started 9-29 1977 Completed 10-4 1977
Date well drilling machine moved off of well 10-4 1977

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Marc Mendez (Drilling Machine Operator) Date 10-5, 1977
Drilling Machine Operator's License No. 1103

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Miller & West (Person, firm or corporation) (Type or print)
Address 5875 Griffin Rd.
[Signed] Marion E. West (Water Well Contractor)
Contractor's License No. 30 Date Oct. 5, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119