

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion:

RECEIVED

AUG 9 1966

WATER WELL REPORT

STATE OF OREGON (Please type or print)

MAR 1, 1966

7603

State Well No. 8/2w-5

State Permit No.

(1) OWNER:

Name RUBBIE FISHER
Address 5155 GIFFIN DR. S.E. SALAM

(2) LOCATION OF WELL:

County Marion Driller's well number
1/4 Section N.E. 5 T. 8 S. R. 2, 21 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 71 ft. to 80 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 3/8 in. by 2 1/2 in.
..... perforations from ft. to ft.
112 perforations from 35 ft. to 42 ft.
340 perforations from 56 ft. to 78 ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE & DRILL CUTTINGS
Depth of seal 20 ft. Was a packer used? No
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 20 ft. below land surface Date 7-1-66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? WEST
Yield: 150 gal./min. with 50 ft. drawdown after 3 hrs.
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 80 ft. Depth of completed well 80 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
BROWN - CLAY	0	22
BLUE - "	22	27
SAND & GRAVEL CEMENTED WITH BLUE CLAY	27	35
200% COARSE GRAVEL WITH BLACK SAND	35	42
SAND & GRAVEL	42	49
CEMENTED WITH BROWN CLAY	49	56
PARTLY CEMENTED BROWN SAND & COARSE GRAVEL	56	80

Work started 6-27-66 19 Completed 7-1-66 19
Date well drilling machine moved off of well 7-2-66 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller-Robinson & West
(Person, firm or corporation) (Type or print)

Address 5545 So. 84th St. S.E.

Drilling Machine Operator's License No. 59

[Signed] Harlan E. Miller
(Water Well Contractor)

Contractor's License No. 37 Date 7-6-66, 19.....